

PUAFER001 Identify, prevent and report potential facility emergency situations

Release: 1

PUAFER001 Identify, prevent and report potential facility emergency situations

Modification History

Release 1. This is the first release of this unit of competency in the PUA Public Safety Training Package.

Application

This unit of competency involves the skills and knowledge required by occupants to identify and prevent the development of facility emergency situations or to minimise their consequences, and to report if emergency protection systems and/or equipment is compromised.

It applies to a broad range of emergencies and covers the work required before an emergency services and/or specialist response team arrives; it does not include the specific use of equipment to prevent facility emergency situations.

The unit has been developed to cover facilities as specified in Australian Standard 3745 and AS 4083. For this unit, as covered by AS 3745 and/or AS4083, occupants are people attending a facility on a permanent or temporary basis such as an employee, contractor, student or resident, but not a visitor or patient and a facility is a building, structure or workplace that is, or may be, occupied by people (occupants).

All aspects of the unit must be undertaken in accordance with legislative requirements, organisational policies and procedures and approved safe practices. It applies to occupants who are required to be 'emergency aware' in their facility.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

Pre-requisite Unit

Not applicable.

Competency Field

Facility Emergency Response

Unit Sector

Public Safety

Approved Page 2 of 5

Elements and Performance Criteria

ELEMENTS

PERFORMANCE CRITERIA

Elements describe the essential outcomes.

Performance criteria describe the performance needed to demonstrate achievement of the element.

- 1 Identify, monitor and report situations that could lead to facility emergencies
- 1.1 Situations that could lead to facility emergencies are identified by the occupant and facility emergency response procedures are followed
- 1.2 Immediate work area and/or public area is routinely checked for situations that could lead to emergencies
- 1.3 High risk activities are monitored to ensure precautions and facility emergency response procedures are followed
- 2 Identify, report and correct situations that could prevent facility emergencies from being safely handled
- **2.1** Relevant emergency protection systems and equipment are identified
- 2.2 Situations that could lead to emergency protection systems and equipment being impaired are identified
- 2.3 Immediate work area is routinely checked for situations that could lead to emergency protection systems and equipment being made inoperable and results of check are reported

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the Companion Volume Implementation Guide.

high risk activities must include three or more of the following relevant to the facility

- handling dangerous goods and hazardous materials including waste
- handling gases

Approved Page 3 of 5

emergency protection systems and equipment must include three or more of the following relevant to the facility

situations that could lead to emergency protection systems and equipment being impaired must include three or more of the following relevant to the facility

- hot work
- manual handling
- manufacturing
- using, mixing and/or moving chemicals
- working around traffic
- working at heights, in confined spaces, in poorly ventilated spaces or around noise subject to permit
- working with plant and machinery
- working with unstable equipment or equipment that has deteriorated
- access, egress and paths of travel
- alarm initiation devices
- any specific dangerous good and/or hazardous chemical antidotes and treatment e.g. corrosives
- automatic fire, leak, spill or movement detectors
- escape equipment
- exit signs and emergency lighting
- facility emergency response procedures contained within the facility emergency plan
- fire or smoke detection,
- fire or smoke doors, fire walls
- first aid kits
- initial response firefighting equipment
- occupant warning and communications systems
- shower and eyewash
- special hazard identification systems
- spill or leak containment equipment
- suppression systems
- emergency equipment not being maintained
- emergency lighting and/or exit lighting being damaged, missing
- impairing exits and/or pathways to exits
- inability to access emergency equipment
- inappropriate or non-compliant storage and/or handling of dangerous goods
- interfering with alarm systems
- not replacing or replenishing used emergency equipment
- not reporting damage to emergency

Approved Page 4 of 5

equipment or facilities

• propping open fire or smoke doors

Unit Mapping Information

This unit replaces and is equivalent to PUAWER001B Identify, prevent and report potential facility emergency situations.

Links

PUA Training Package Companion Volume Implementation Guide is found in VETNet - https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=3eca5672-6d5a-410b-8942-810d0ba05bbf

Approved Page 5 of 5