



Australian Government

**UEGNSG207 Coordinate construction,
laying and testing of gas distribution
pipelines**

Release: 1

UEGNSG207 Coordinate construction, laying and testing of gas distribution pipelines

Modification History

Release 1: This is the first release of this unit of competency in the UEG Gas Industry Training Package.

Application

This unit involves the skills and knowledge required to coordinate construction, laying and testing of gas distribution pipelines and associated equipment.

It includes notifying other services, communicating with appropriate person/s, ensuring the correct materials, tools and equipment are used and completing relevant documentation.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

Pre-requisite Unit

Not applicable.

Competency Field

Gas Distribution

Unit Sector

Gas Industry

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Prepare to coordinate pipeline installation

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

1.1 Location of services are verified and alignment of gas main and associated equipment are confirmed, as necessary, by site inspection in accordance with work schedule and workplace procedures

1.2 Job requirements and workplace procedures for the

work are obtained for all work sites and communicated to relevant person/s in accordance with workplace procedures

- 1.3** Work health and safety (WHS)/occupational health and safety (OHS), environmental and sustainable energy policies and procedures related to the work are obtained, applied and communicated with relevant person/s in accordance with workplace procedures
- 1.4** Work is prioritised and sequenced for completion within acceptable timeframes following consultation with relevant person/s in accordance with workplace procedures
- 1.5** Hazards are identified, WHS/OHS risks are assessed and control measures prioritised, implemented and monitored in accordance with workplace procedures
- 1.6** Relevant work permits are obtained to access, isolate/de-isolate systems and perform the work in accordance with regulatory requirements and workplace procedures
- 1.7** Person/s, equipment, tools and personal protective equipment (PPE) required for the job are identified, scheduled, obtained checked for correct operation and safety in accordance with workplace procedures
- 1.8** Communication with authorised person/s, authorities, clients and land-owners is conducted and work coordinated in accordance with work schedule and workplace procedures
- 1.9** Site is prepared to minimise risk and damage to property, commerce and individuals in accordance with the work schedule and workplace procedures
- 1.10** Person/s participating in the work are briefed and responsibilities coordinated and confirmed in accordance with job requirements and workplace procedures
- 1.11** Road signs, barriers and warning devices are positioned in accordance with job requirements, workplace procedures and traffic management plan

2 Coordinate construction, laying and testing of

- 2.1** WHS/OHS and environment risk control measures, schedule of work and workplace procedures for carrying

pipelines

out work are followed

- 2.2 Hazardous activities are conducted safely and currency confirmed in accordance with regulatory requirements and workplace procedures
- 2.3 Construction, laying and testing of gas distribution pipelines is coordinated to ensure completion in agreed timeframe and to required standards with a minimum of waste in accordance with job requirements and workplace procedures
- 2.4 Construction, laying and testing work is coordinated in accordance with the work schedule and workplace procedures
- 2.5 Hazard warnings and safety signs are recognised, hazards and WHS/OHS risks assessed and reported to authorised person/s for directions in accordance with workplace procedures
- 2.6 Unplanned events encountered when coordinating the construction, laying and testing work are identified and actioned in accordance with workplace procedures

3 Complete the coordination of pipeline construction and laying and relevant documentation

- 3.1 Final inspections of work are undertaken, checked against work schedule for conformance and anomalies reported in accordance with workplace procedures
- 3.2 Accidents and injuries are reported, as required, in accordance with workplace procedures
- 3.3 Work site is rehabilitated, cleaned up and made safe in accordance with workplace procedures
- 3.4 Tools, equipment and any surplus resources and materials are cleaned, checked and returned to storage in accordance with workplace procedures
- 3.5 Relevant work permit/s are signed off and pipeline returned to service in accordance with job requirements and workplace procedures
- 3.6 Work completion records, reports and documentation are completed, processed and appropriate person/s notified in accordance with workplace procedures

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the UEG Gas Industry Training Package Companion Volume Implementation Guide.

tools and equipment must include at least three (3) of the following:

- excavation
- trenching
- shoring
- stitch bore
- horizontal drilling
- directional drilling

pipe connections must include at least four (4) of the following: :

- nylon (polymide) pipeline laying techniques
- nylon gluing
- connection of nylon to other materials
- nylon stop off
- unplasticised polyvinyl chloride (uPVC) pipeline laying techniques
- uPVC solvent cemented joints
- uPVC moulded joints
- uPVC stop off
- uPVC couplings or flanges
- connection of uPVC to other material

procedures must include at least five (5) of the following:

- polyethylene (PE) pipeline laying techniques
- large diameter PE
- PE electro fusion
- PE butt fusion
- saddle fusion
- socket fusion
- PE stop off
- compression couplings or flanges
- connection of PE to other materials
- practical application of installation and maintenance of plastic pipe systems

procedures must include at least two (2) of the following:

- steel pipeline coating repair
- steel pipeline coating testing (jeeper)
- steel, field joint coating

procedures must include at least three (3) of the following:

- connection of PE to steel mains
- steel mains welding
- steel mains repair
- sleeve application
- clamp application
- hot tap and stopple

isolation methods must include at least two (2) of the following:

- high pressure stop off
- bagtube
- squash off jacks
- squash off pliers

Unit Mapping Information

This unit replaces and is equivalent to UEGNSG207B Coordinate construction, laying and testing of gas distribution pipelines.

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=6a6c032e-ffcb-4f3d-8063-415efbd261e8>