



Australian Government

Department of Education, Employment and Workplace Relations

UETTDRCJ24A Joint and maintain energised low voltage underground paper insulated cables

Release: 1

UETTDRJ24A Joint and maintain energised low voltage underground paper insulated cables

Modification History

Not applicable.

Unit Descriptor

Unit Descriptor

1) Scope:

1.1) Descriptor

This Competency Standard Unit covers the jointing and maintenance of energised low voltage underground paper insulated cables according to established enterprise procedures. It covers the use of specialised live working equipment, tools and devices, the issuing and/or accepting electrical access permits and/or relevant working documentation and the undertaking of authorised cable testing procedures. It also encompasses the pre-commissioning tests and the updating of system data/maintenance records.

Application of the Unit

Application of the Unit 2)

This Competency Standard Unit is intended to augment formally acquired competencies. It is suitable for employment-based programs under an approved contract of training.

Licensing/Regulatory Information

License to practice 3)

The skills and knowledge described in this unit may require a licence/registration to practice in the work place subject to regulations for undertaking of electrical work. Practice in workplace and during training is also subject to regulations directly related to Occupational Health and

License to practice

3)

Safety, electricity/telecommunications/gas/water industry safety and compliance, industrial relations, environmental protection, anti discrimination and training.

Commonwealth, State/Territory or Local Government legislation and regulations may exist that limits the age of operating certain equipment.

Pre-Requisites

Prerequisite Unit(s)

4)

Competencies

4.1)

Granting of competency in this unit shall be made only after competency in the following unit(s) has/have been confirmed.

Where pre-requisite pathways have been identified. All competencies in the Common Unit Group must be have been completed plus all the competencies in one (1) of the identified Pathway Unit Group(s):

Common Unit Group

Unit Code	Unit Title
UEENEEE101A	Apply Occupational Health and Safety regulations, codes and practices in the workplace
UEENEEE102A	Fabricate, assemble and dismantle utilities industry components
UEENEEE104A	Solve problems in d.c. Circuits
UEENEEE105A	Fix and secure electrotechnology equipment
UEENEEE107A	Use drawings, diagrams, schedules, standards, codes and specifications
UEENEEG101A	Solve problems in electromagnetic devices and related circuits
UEENEEG102A	Solve problems in low voltage a.c. Circuits

Prerequisite Unit(s)

4)

UETTDRCJ21A	Lay ESI electrical cables
UETTDRCJ26A	Install and maintain de-energised low voltage underground polymeric cables.
UETTDRCJ27A	Install and maintain de-energised high voltage underground polymeric cables.
UETTDREL11A	Apply sustainable energy and environmental procedures
UETTDREL12A	Operate plant and equipment near live electrical conductors and apparatus
UETTDREL16A	Working safely near live electrical apparatus
UETTDRLS41A	Install network infrastructure electrical equipment
UETTDRLS42A	Maintain network infrastructure electrical equipment
UETTDRLS55A	Install and maintain low voltage underground services

Literacy and numeracy skills

4.2)

Participants are best equipped to achieve this unit if they have reading, writing and numeracy skills indicated by the following scales. Description of each scale is given in Volume 2, Part 3 “Literacy and Numeracy”.

Reading 3 Writing 3 Numeracy 3

Employability Skills Information

Employability Skills 5)

The required outcomes described in this unit of competency contain applicable facets of Employability Skills. The Employability Skills Summary of the qualification in which this unit of competency is packaged will assist in identifying Employability Skill requirements.

Elements and Performance Criteria Pre-Content

6) Elements describe the essential outcomes of a competency standard unit
Performance Criteria describe the required performance needed to demonstrate achievement of the element.
Assessment of performance is to be consistent with the Evidence Guide.

Elements and Performance Criteria

ELEMENT

PERFORMANCE CRITERIA

1 Prepare for the jointing and maintenance of energised LV underground paper insulated cables	1.1 Works schedule(s), including drawings, plans, requirements, established procedures, and material lists, are received, analysed and confirmed, if necessary, by site inspection
	1.2 Relevant requirements and established procedures for the work are communicated to all personnel and identified for all work sites
	1.3 OHS policies and procedures related to requirements and established procedures for the jointing and maintenance of energised LV underground paper insulated cables are obtained and confirmed for the purposes of the work to be performed and communicated
	1.4 Work is prioritised and sequenced following consultation with others for completion within acceptable timeframes and in accordance with established procedures
	1.5 Hazards are identified, OHS risks assessed and control measures are prioritised, implemented

ELEMENT

PERFORMANCE CRITERIA

- and monitored including emergency exits kept clear according to established procedures.
- 1.6 Relevant work permits are obtained to access and perform work according to requirements and/or established procedures
 - 1.7 Resources including personnel, equipment, tools and personal protective equipment required for the job are obtained and confirmed in working order.
 - 1.8 Specialist equipment for live working is inspected and confined in working order as per requirements and established procedures
 - 1.9 Relevant personnel at work site are confirmed current in First Aid and other related work procedures according to requirements
 - 1.10 Liaison and communication issues with other/authorised personnel, authorities, clients and land owners are resolved to carry out work where necessary.
 - 1.11 Site is prepared according to the work schedule and to minimise risk and damage to property, commerce, and individuals in accordance with established procedures
 - 1.12 Personnel participating in the work, including plant operators and contractors, are fully briefed and respective responsibilities confirmed where applicable in accordance with established procedures
- 2 Carry out jointing and maintenance of energised LV underground paper insulated cables
- 2.1 OHS, sustainable energy and environmental principles and practices to reduce the incidents of accidents and minimise waste are monitored and followed in accordance with requirements and/or established procedures
 - 2.2 Lifting, climbing, working in confined spaces and aloft, and use of power tools/equipment, techniques and practices are safely followed and, currency according to requirements confirmed

ELEMENT

PERFORMANCE CRITERIA

- 2.3 Essential knowledge and associated skills are applied in the safe jointing and maintenance of energised LV underground paper insulated cables to ensure completion in an agreed timeframe and, to quality standards with a minimum of waste according to requirements
- 2.4 Cable(s), underground equipment, associated hardware and surrounds are prepared in accordance with established procedures
- 2.5 Joint and termination procedures of energised LV cable(s) are carried out in accordance with the work schedule and requirements/established procedures
- 2.6 Authorised cable testing procedures and fault identification and location process are implemented in accordance with requirements and established procedures
- 2.7 Maintenance, including repair and/or replacement of energised LV underground paper insulated cables is carried out, in accordance with the work schedule and requirements/established procedures
- 2.8 Hazard warnings and safety signs are recognised and hazards and assessed OHS risks are reported to the immediate authorised persons for directions according to established procedures.
- 2.9 Unplanned events in the jointing and maintenance of energised LV underground paper insulated cables are undertaken within the scope of established procedures
- 2.10 Known solutions to a variety of problems are applied using acquired essential knowledge and associated skills
- 2.11 Ongoing checks of quality of the work are undertaken in accordance with instructions and established procedures
- 2.12 OHS, sustainable energy and environmental principles and practices to reduce the incidents of

ELEMENT

PERFORMANCE CRITERIA

		accidents and minimise waste are monitored and followed in accordance with requirements and/or established procedures
3	Complete the jointing and maintenance of energised LV underground paper insulated cables	<p>3.1 Work undertaken is checked against works schedule for conformance with requirements and, anomalies reported in accordance with established procedures</p> <p>3.2 Accidents and/or injuries are reported in accordance with requirements/established procedures, where applicable.</p> <p>3.3 Tools, equipment and any surplus resources and materials are, where appropriate, cleaned, checked and returned to storage or disposed of in accordance with established procedures</p> <p>3.4 Relevant work permit(s) are signed off and, jointing and maintenance of energised LV underground paper insulated cables are returned to service in accordance with requirements</p> <p>3.5 Works completion records, reports, as installed /modified drawing and/or documentation and information are finalised and processed and appropriate personnel notified</p>

Required Skills and Knowledge

REQUIRED SKILLS AND KNOWLEDGE

8) Essential knowledge and associated skills (EKAS): This describes the essential skills and knowledge and their level, required for this unit.

Evidence shall show that knowledge has been acquired of jointing and maintaining energised LV underground paper insulated cables.

All knowledge and skills detailed in this unit should be contextualised to current industry practices and technologies.

KS01-TCJ24A LV energised working practices for paper lead cable jointing

Evidence shall show an understanding of the safe working on energised low voltage equipment to an extent indicated by the following aspects:

T1 Standards, codes, Commonwealth, State/Territory/local government legislation, supply authority regulations and or enterprise requirements

T2 Safety precautions specific to working on or near energised low voltage conductors encompassing:

- Safe working practices and procedures
- Identification of hazards, assessment and control of OHS risks
- Types, selection, maintenance and use of personal protective equipment

T3 Work on or near energised LV paper lead cables encompassing:

- Types and function of specialised tools
- Safe working practices when using specialised tools
- Methods of using specialised tools
- Safe procedures for work on panels and in cubicles on or near energised LV paper lead cables

Evidence Guide

EVIDENCE GUIDE

9) This provides essential advice for assessment of the unit of competency and must be read in conjunction with the performance criteria and the range statement of the unit of competency and the Training Package Assessment Guidelines.

The Evidence Guide forms an integral part of this Competency Standard Unit and shall be used in conjunction with all component parts of this unit and, performed in accordance with the Assessment Guidelines of this Training Package.

Overview of Assessment 9.1)

Longitudinal competency development approaches to assessment, such as Profiling, require data to be reliably gathered in a form that

can be consistently interpreted over time. This approach is best utilised in Apprenticeship programs and reduces assessment intervention. It is the Industry's preferred model for apprenticeships. However, where summative (or final) assessment is used it is to include the application of the competency in the normal work environment or, at a minimum, the application of the competency in a realistically simulated work environment. It is recognised that, in some circumstances, assessment in part or full can occur outside the workplace. However, it must be in accord with Industry and, Regulatory policy in this regard.

Methods chosen for a particular assessment will be influenced by various factors. These include the extent of the assessment, the most effective locations for the assessment activities to take place, access to physical resources, additional safety measures that may be required and the critical nature of the competencies being assessed.

The critical safety nature of working with electricity, electrical equipment, gas or any other hazardous substance/material carries risk in deeming a person competent. Hence, sources of evidence need to be 'rich' in nature so as to minimise error in judgment. Activities associated with normal every day work have a bearing on the decision as to how much and how detailed the data gathered will contribute to its 'richness'. Some skills are more critical to safety and operational requirements while the same skills may be more or less frequently practiced. These points are raised for the assessors to consider when choosing an assessment method and developing assessment instruments. Sample assessment instruments are included for Assessors in the Assessment Guidelines of this Training Package.

Critical aspects of evidence required to demonstrate competency in this unit 9.2)

Before the critical aspects of evidence are considered all prerequisites shall be met.

Evidence for competence in this unit shall be considered holistically. Each element and associated performance criteria shall be demonstrated on at least two occasions in accordance with the "Assessment Guidelines – UET12". Evidence shall also comprise:

- A representative body of performance criteria demonstrated within the timeframes typically expected of the discipline, work function and industrial environment. In particular this

shall incorporate evidence that shows a candidate is able to:

- Implement Occupational Health and Safety workplace procedures and practices including the use of risk control measures as specified in the performance criteria and range; and
- Apply sustainable energy principles and practices as specified in the performance criteria and range; and
- Demonstrate an understanding of the essential knowledge and associated skills as described in this unit to such an extent that the learner’s performance outcome is reported in accordance with the preferred approach; namely a percentile graded result, where required by the regulated environment; and
- Demonstrate an appropriate level of employability skills; and
- Conduct work observing the relevant Anti Discrimination legislation, regulations, policies and workplace procedures; and
- Demonstrated performance across a representative range of contexts from the prescribed items below:

Range of tools, equipment, materials, procedures, workplaces or other variables		
Group No	The minimum number of items on which skill is to be demonstrated	Item List
A	At least one of the following:	LV paper/lead LV paper/aluminium
B	At least two of the following:	Tee-off joints Straight through joints Parallel branch
C	At least one of the following:	Transformers LV switchboards Pillars/turrets Lighting columns Ring main units Chamber substations Busbar/termination boxes Links Termination boxes Control gear

D	At least one of the following:	Resin filled boxes Compound filled boxes Polymeric tape Heat shrink 'slip-on' moulds Pre-stretched polymeric
E	At least two of the following:	Compression joints Soldered joints Mechanical connectors Soldered lugs Compression lugs
F	All of the following:	Voltage detecting instruments Insulation resistance testers Cable identification equipment Moisture testing equipment Phase rotation instruments Specialised live working equipment/tools
G	All of the following:	Temporary earth bonding/bridging, Insulating covers/matting Insulating tooling/ gloves
H	At least one occasion	Dealing with an unplanned event by drawing on essential knowledge and associated skills to provide appropriate solutions incorporated in the holistic assessment with the above listed items.

Context of and specific resources for assessment 9.3)

This unit should be assessed as it relates to normal work practice using procedures, information and resources typical of a workplace. This should include:

- OHS policy and work procedures and instructions.
- Suitable work environment, facilities, equipment and materials to undertake actual work as prescribed by this Competency Standard Unit.

In addition to the resources listed above, in context of and specific resources for assessment, evidence should show demonstrated competency working below ground, in limited spaces, with different structural/construction types and method and in a variety of environments.

Method of assessment 9.4)

This Competency Standard Unit shall be assessed by methods given in Volume 1, Part 3 “Assessment Guidelines”.

Note:

Competent performance with inherent safe working practices is expected in the Industry to which this Competency Standard Unit applies. This requires that the specified essential knowledge and associated skills are assessed in a structured environment which is primarily intended for learning/assessment and incorporates all necessary equipment and facilities for learners to develop and demonstrate the essential knowledge and associated skills described in this unit.

Concurrent assessment and relationship with other units 9.5)

For optimisation of training and assessment effort, competence in this unit may be assessed concurrently with the following units:

UETTDRCJ2 Joint and maintain energised low voltage
8A underground polymeric cables

Range Statement

RANGE STATEMENT

10) This relates to the unit of competency as a whole providing the range of contexts and conditions to which the performance criteria apply. It allows for different work environments and situations that will affect performance.

This Competency Standard Unit shall be demonstrated in relation to the jointing and maintenance of energised low voltage underground paper insulated cables and covers the jointing, repair and replacement of cables using specialised live working equipment, tools and devices.

Installation and Maintenance may include the repair and replacement of cables and associated hardware.

Types of cables includes: Paper-Insulated which refers to LV solid paper insulated metal sheathed.

Underground equipment may include straight and branch joints, ring main units, distribution fuse boxes, pad mount and ground transformers, chamber substations, LV switchboards, pillars/turrets, busbar/termination boxes, street lighting control gear and street lighting columns.

Test and recording equipment includes voltage detectors, tong ammeters, cable identification equipment and insulation resistance testers.

Jointing and terminating materials include compound and resin filled boxes, paper tape materials, polymeric tape materials, polymeric heat shrink materials, "slip-on" moulded components and pre-stretched polymeric materials, compression and solder lugs and ferrules and mechanical connectors.

Jointing and terminating locations include, ring main units, distribution fuse boxes, pad mount and ground transformers, chamber substations, LV switchboards, pillars/turrets, busbar/termination boxes, street lighting control points and street lighting columns.

The following constants and variables included in the element/performance criteria in this unit are fully described in the Definitions Section 1 of this volume and form an integral part of the Range Statement of this unit:

- Appropriate and relevant persons (see Personnel)
- Appropriate authorities
- Appropriate work platform.
- Assessing risk
- Assessment
- Authorisation
- Confined space
- Diagnostic, testing and restoration.
- Documenting detail work events, record keeping and or storage of information.
- Drawings and specifications
- Emergency
- Environmental and sustainable energy procedures

RANGE STATEMENT

- Environmental legislation.
- Environmental management documentation.
- Established procedures.
- Fall prevention
- Hazards
- Identifying hazards
- Inspect
- Legislation
- MSDS
- Notification.
- OHS practices
- OHS issues
- Permits and/or permits to work
- Personnel.
- Quality assurance systems.
- Requirements.
- Testing procedures
- Work clearance systems.

Unit Sector(s)

Not applicable.

Competency Field

Competency Field **11)**

Cable Jointing