



**Australian Government**

# **CPCPFS2021 Connect static storage tanks for fixed fire protection systems**

**Release: 2**

# CPCPFS2021 Connect static storage tanks for fixed fire protection systems

## Modification History

- Release 2 This version first released with CPC Construction, Plumbing and Services Training Package Release 5.1.  
Duplicate Element and Performance Criteria 1.3 deleted.
- Release 1 This version first released with CPC Construction, Plumbing and Services Training Package Release 5.0.  
Supersedes and is equivalent to CPCPFS2021A Connect static storage tanks for fixed fire protection systems. Updated to meet the Standards for Training Packages 2012.

## Application

This unit specifies the skills and knowledge required to connect storage tanks to fixed fire protection systems.

In some jurisdictions, this unit of competency may form part of accreditation, licensing, legislative, regulatory or certification requirements.

## Pre-requisite Unit

CPCPCM2043 Carry out WHS requirements

## Unit Sector

Plumbing

## Elements and Performance Criteria

| Elements describe the essential outcomes. | Performance criteria describe what needs to be done to demonstrate achievement of the element.                                                                                                                    |
|-------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 Identify installation requirements.     | 1.1 Determine storage tank for fixed fire protection systems requirements from relevant job plans and specifications, codes, Australian Standards, manufacturer's specifications and jurisdictional requirements. |
|                                           | 1.2 Identify and apply workplace policies and procedures, work health and safety (WHS) and environmental                                                                                                          |

requirements.

- |                                  |     |                                                                                                                                                                                                                                              |
|----------------------------------|-----|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2 Prepare for work.              | 2.1 | Create a materials list and collect materials.                                                                                                                                                                                               |
|                                  | 2.2 | Select and check the serviceability of appropriate tools and equipment including personal protective equipment (PPE).                                                                                                                        |
| 3 Install and test storage tank. | 3.1 | Connect storage tank and associated pipework.                                                                                                                                                                                                |
|                                  | 3.2 | Apply pipe supports and fixings.                                                                                                                                                                                                             |
|                                  | 3.3 | Connect tank piping, associated valves and materials to the suction side of the fire pumpset.                                                                                                                                                |
|                                  | 3.4 | Connect make up and quick fill pipework, associated valving and supports according to job specifications, relevant job plans and specifications, codes, Australian Standards, manufacturer's specifications and jurisdictional requirements. |
|                                  | 3.5 | Check jointing systems to ensure compliance with relevant job plans and specifications, codes, Australian Standards, manufacturer's specifications and jurisdictional requirements.                                                          |
|                                  | 3.6 | Conduct pressure testing on installed system.                                                                                                                                                                                                |
|                                  | 3.7 | Test and confirm correct operation of quick fill and make up lines and valving.                                                                                                                                                              |
|                                  | 3.8 | Record test data in required format.                                                                                                                                                                                                         |
|                                  | 3.9 | Complete documentation according to relevant job plans and specifications, codes, Australian Standards, manufacturer's specifications and jurisdictional requirements.                                                                       |
| 4 Clean up.                      | 4.1 | Clear the work area, and dispose of, reuse or recycle materials in accordance with state and territory legislation and workplace policies and procedures.                                                                                    |
|                                  | 4.2 | Clean tools and equipment, check for serviceability and report any damage, and store and secure.                                                                                                                                             |

## Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

## Unit Mapping Information

Supersedes and is equivalent to CPCPFS2021A Connect static storage tanks for fixed fire protection systems.

## Links

Companion volumes to this training package are available at the VETNet website -  
<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=7e15fa6a-68b8-4097-b099-030a5569b1ad>