



**Australian Government**

# **Assessment Requirements for CPPFES2010 Inspect and test fire hose reels**

**Release: 1**

# Assessment Requirements for CPPFES2010 Inspect and test fire hose reels

## Modification History

Release 1 This version first released with CPP Property Services Training Package Release 13.0.

Supersedes and is equivalent to CPPFES2010A Inspect and test fire hose reels. Unit updated to meet the Standards for Training Packages 2012.

## Performance Evidence

To demonstrate competency, a candidate must meet the elements and performance criteria of this unit by inspecting and testing 20 fire hose reels at a minimum of five different sites:

- five of these fire hose reels must be installed in a recess, cupboard or cabinet
- a total of two regulatory non-compliances associated with access, usability or coverage of the installed fire hose reels must be identified and documented.

## Knowledge Evidence

To be competent in this unit, a candidate must demonstrate knowledge of:

- action to take when a breach of regulation, work health and safety (WHS) or other policy occurs when inspecting and testing fire hose reels
- implications of not complying with regulatory requirements when inspecting, testing and replacing fire hose reels
- key features of legislation, regulations, codes and Australian Standards relevant to the inspection, testing and replacement of fire hose reels:
  - environmental protection
  - maintenance schedules
  - National Construction Code (NCC) and deemed-to-satisfy requirements
  - reasons why activities related to work on reticulated water systems are restricted to licensed plumbers
  - records and documentation
  - steps and processes to be followed when unusual or non-documented faults are found
- methods for conducting flow testing
- types and purpose of tools, equipment and materials used when inspecting and testing fire hose reels:
  - hand and power tools
  - flow testing equipment
  - personal protective equipment (PPE)

- types and purpose of fire hose reels:
  - recess-mounted
  - swing-hinged
  - wall-mounted
- types and purpose of fire hose reel components:
  - clamps
  - hoses
  - labels
  - nozzles
  - O-rings
  - valves
- types of defects that may be discovered when inspecting and testing fire hose reels
- types of fire hose reel repair and replacement activities which must be referred to a licensed tradesperson
- workplace requirements for inspecting and testing fire hose reels:
  - maintenance of tools and equipment
  - WHS, including hazard and risk identification and control.

## Assessment Conditions

Assessors must meet the requirements for assessors contained in the Standards for Registered Training Organisations.

Assessment must be conducted in the workplace or a simulated workplace using realistic conditions, materials, activities, responsibilities, procedures, safety requirements and environmental considerations.

Candidates must have access to documentation, tools, equipment, spare parts and operational fire hose reels required to achieve the performance evidence.

## Links

Companion volumes to this training package are available at the VETNet website - <https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=6f3f9672-30e8-4835-b348-205dfcf13d9b>