



Australian Government

**Assessment Requirements for CPPFES2035
Identify, inspect and test fire and smoke
doors**

Release: 1

Assessment Requirements for CPPFES2035 Identify, inspect and test fire and smoke doors

Modification History

Release 1 This version first released with CPP Property Services Training Package Release 13.0.

Supersedes and is equivalent to CPPFES2035A Identify, inspect and test fire and smoke doors. Unit updated to meet the Standards for Training Packages 2012.

Performance Evidence

To demonstrate competency, a candidate must meet the elements and performance criteria of this unit by identifying, inspecting and testing 20 fire or smoke doors that are installed across two different sites, including:

- at least one fire door and one smoke door
- three different types of fire or smoke doors.

Knowledge Evidence

To be competent in this unit, a candidate must demonstrate knowledge of:

- action to take when a breach of regulation, work health and safety (WHS) or other policy occurs when identifying, inspecting and testing fire and smoke doors
- correct installation procedures and dangers of incorrect installation of fire and smoke doors
- fire and smoke doors and fire shutter variables, including types, components, hardware, seals and wall types
- implications of not complying with regulatory requirements when inspecting and testing fire and smoke doors
- key features of legislation, regulations, codes and Australian Standards relevant to identifying, inspecting and testing fire and smoke doors and fire shutters:
 - fire and smoke containment
 - maintenance schedules
 - National Construction Code (NCC) and deemed-to-satisfy requirements
 - records and documentation
- key physical features, definition of, and purpose of fire and smoke doors and fire shutters
- operational requirements for inspecting and testing fire and smoke doors and fire shutters
- principles of passive fire protection related to overall fire safety systems
- procedures for determining fire resistance levels

- range of fire and smoke door tags
- technical terms relating to fire and smoke door and fire shutter inspection and testing
- workplace requirements for identifying, inspecting and testing fire and smoke doors:
 - maintenance of tools and equipment
 - WHS, including hazard and risk identification and control.

Assessment Conditions

Assessors must meet the requirements for assessors contained in the Standards for Registered Training Organisations.

Assessment must be conducted in the workplace or a simulated workplace using realistic conditions, materials, activities, responsibilities, procedures, safety requirements and environmental considerations.

Candidates must have access to drawings, documentation, tools, equipment and installed fire and smoke doors required to achieve the performance evidence.

Links

Companion volumes to this training package are available at the VETNet website - <https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=6f3f9672-30e8-4835-b348-205dfcf13d9b>