



Australian Government

Department of Education, Employment and Workplace Relations

NWP273A Monitor, operate and report ultraviolet irradiation disinfection systems

Revision Number: 1

NWP273A Monitor, operate and report ultraviolet irradiation disinfection systems

Modification History

Not applicable.

Unit Descriptor

Unit descriptor This unit of competency describes the outcomes required to monitor and operate ultraviolet (UV) irradiation disinfection systems and to report on microbiological quality control.

Application of the Unit

Application of the unit This unit supports the attainment of skills and knowledge required for operational staff with specific responsibility for ensuring that UV irradiation disinfection systems comply with organisational requirements.

Licensing/Regulatory Information

Not applicable.

Pre-Requisites

Not applicable.

Employability Skills Information

Employability skills This unit of competency contains employability skills.

Elements and Performance Criteria Pre-Content

Elements describe the essential outcomes of a unit of competency. Performance criteria describe the required performance needed to demonstrate achievement of the element. Where ***bold italicised*** text is used, further information is detailed in the required skills and knowledge, and the range statement. Assessment of performance is to be consistent with the evidence guide.

Elements and Performance Criteria

ELEMENT	PERFORMANCE CRITERIA
1 Plan and prepare for work.	1.1 Determine work requirements according to <i>legislative and organisational requirements</i> . 1.2 Select and check <i>equipment and tools</i> required to meet safety requirements of task and site. 1.3 Select, fit and use personal protective equipment.
2 Monitor system performance.	2.1 Monitor <i>UV irradiation disinfection systems</i> according to agreed schedule and procedures. 2.2 Collect process samples and conduct standard microbiological <i>tests</i> as required. 2.3 Maintain and monitor relevant OHS requirements. 2.4 Collect and report process data according to organisational and disinfection system requirements.
3 Maintain and operate UV irradiation disinfection system.	3.1 Carry out routine inspections of <i>system components</i> according to organisational requirements. 3.2 Clean and replace system components as required. 3.3 Operate UV lamp sequencing according to organisational requirements.
4 Complete documentation.	4.1 Produce information relating to UV irradiation disinfection system maintenance and operation, according to organisational requirements. 4.2 Review information and contribute to enterprise processes for continuous improvement and incident management.

Required Skills and Knowledge

REQUIRED SKILLS AND KNOWLEDGE

This describes the essential skills and knowledge and their level, required for this unit.

Required skills:

- identify and respond to operational problems
- produce reports and logs
- use safety equipment
- use UV-absorbent personal protective equipment
- safe use of cleaning chemicals
- follow plans, charts and instructions
- apply policies, standard operating procedures and regulatory standards
- communicate effectively
- work effectively as part of a team
- use communication equipment
- give and receive instructions
- perform work-related calculations
- operate computerised equipment
- identify control system faults
- identify hazards
- perform microbiological sampling
- use literacy skills in regard to verbal and written communication in the workplace
- interpret material safety data sheets (MSDS).

Required knowledge:

- properties of UV irradiation
- microbiological water quality guidelines
- UV irradiation disinfection system layout, including components
- lock-out procedures for mechanical and electrical installations
- policies, standard operating procedures and legislation
- communication systems
- safe use of cleaning chemicals and prevention of associated hazards
- risk factors and potential hazards associated with UV irradiation systems
- UV irradiation generation equipment operation, capacity and limitations
- effects of weather and conditions on operation of site or plant
- MSDS.

Evidence Guide

EVIDENCE GUIDE

The evidence guide provides advice on assessment and must be read in conjunction with the performance criteria, required skills and knowledge, the range statement and the Assessment Guidelines for the Training Package.

Critical aspects for assessment and evidence required to demonstrate competency in this unit

The candidate should demonstrate the ability to monitor, operate and report on UV irradiation disinfection systems by:

- scheduling work
- selecting and using appropriate tools and equipment, including personal protective equipment
- monitoring UV irradiation disinfection systems
- collecting process samples and performing standard tests
- maintaining and operating UV irradiation disinfection systems
- collecting and reporting process data
- producing reports.

Context of and specific resources for assessment

Access to the workplace and resources including:

- documentation that should normally be available in a water industry organisation
- relevant codes, standards and government regulations.

Where applicable, physical resources should include equipment modified for people with disabilities.

Access must be provided to appropriate learning and assessment support when required.

Assessment processes and techniques must be culturally appropriate, and appropriate to the language and literacy capacity of the candidate and the work being performed.

Validity and sufficiency of evidence requires that:

- competency will need to be demonstrated over a period of time reflecting the scope of the role and the practical requirements of the workplace
- where the assessment is part of a structured learning experience the evidence collected must relate to a number of performances assessed at different points in time and separated by further learning and practice
- a decision of competence should only be made when the assessor has complete confidence in the

EVIDENCE GUIDE

person's competence over time and in various contexts

- all assessment that is part of a structured learning experience must include a combination of direct, indirect and supplementary evidence
- where assessment is for the purpose of recognition (RCC/RPL), the evidence provided will need to be authenticated and show that it represents competency demonstrated over a period of time
- assessment can be through simulated project-based activity and must include evidence relating to each of the elements in this unit.

In all cases where practical assessment is used it will be combined with targeted questioning to assess the underpinning knowledge. Questioning will be undertaken in a manner appropriate to the skill levels of the operator and cultural issues that may affect responses to the questions, and will reflect the requirements of the competency and the work being performed.

Range Statement

RANGE STATEMENT

The range statement relates to the unit of competency as a whole. It allows for different work environments and situations that may affect performance. ***Bold italicised*** wording, if used in the performance criteria, is detailed below. Add any essential operating conditions that may be present with training and assessment depending on the work situation, needs of the candidate, accessibility of the item, and local industry and regional contexts.

Legislative and organisational requirements may include:

- relevant federal and state or territory legislation and regulations
- codes of practice, associated standards and guidance material
- documented organisational policies, manuals and induction programs
- relevant community planning and development agreements, such as land care agreements.

Equipment and tools may include:

- electronic monitoring and metering systems
- recording systems
- basic hand and power tools
- sampling and laboratory testing equipment
- computerised equipment
- personal protective equipment, such as:
 - UV-absorbent face shields
 - UV-absorbent safety goggles
 - UV-absorbent protective clothing.

UV irradiation disinfection systems may include:

- low pressure mercury lamps
- medium pressure mercury lamps.

Tests may include:

- UV absorbance
- turbidity
- suspended solids
- iron
- lamp intensity
- hardness.

UV irradiation system components may include:

- power supply
- ballast
- lamps
- sleeves
- racks.

Unit Sector(s)

Not applicable.

Competency field

Competency field Treatment