



Australian Government

PUAFIR206 Check installed fire safety systems

Release: 1

PUAFIR206 Check installed fire safety systems

Modification History

Release 1. This is the first release of this unit of competency in the PUA Public Safety Training Package.

Application

This unit of competency involves the skills and knowledge required to locate, identify and check the status of installed fire safety systems.

The unit applies to personnel required to locate, identify and check the status of installed fire safety systems. Work at this level is performed under direct supervision and instruction.

The fire sector is those sections of government departments, statutory authorities or organisations that have responsibility under jurisdictional arrangements for the delivery of firefighting and fire management services.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

Pre-requisite Unit

Not applicable.

Competency Field

Fire

Unit Sector

Fire

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Locate and identify installed fire safety systems

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

1.1 Installed fire safety systems are identified and located in buildings

- | | | |
|--|------------|--|
| | 1.2 | Onsite visual identification of installed fire safety systems and mode of operation is confirmed and reported through direct chain of command |
| 2 Check and monitor the status of fire safety systems | 2.1 | Installed fire safety systems are checked, in accordance with organisational procedures |
| | 2.2 | Status of installed fire safety systems is monitored and irregularities such as faults and isolation of individual functions are identified and reported, in accordance with organisational procedures |

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the Companion Volume Implementation Guide.

- fire safety systems must include three or more of the following
- alternative fire suppression system
 - fire detection systems
 - fire hydrant and hydrant booster system
 - fire indicator panels, occupant warning and communications systems
 - fire sprinklers and sprinkler booster system
 - smoke hazards management and ancillary systems

Unit Mapping Information

This unit replaces and is equivalent to PUAFIR206B Check installed fire safety systems.

Links

PUA Training Package Companion Volume Implementation Guide is found in VETNet - <https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=3eca5672-6d5a-410b-8942-810d0ba05bbf>