



**Australian Government**

# **PUAFIR314 Utilise installed fire safety systems**

**Release: 1**

# PUAFIR314 Utilise installed fire safety systems

## Modification History

**Release 1.** This is the first release of this unit of competency in the PUA Public Safety Training Package.

## Application

This unit of competency involves the skills and knowledge required to operate and reinstate installed fire safety systems, to operate occupant warning systems and to apply emergency procedures.

The unit applies to personnel required to locate fire safety systems in a building and to operate these systems to support fire suppression activities. These personnel will also be required to utilise these systems to support the evacuation of occupants and other emergency services personnel from the building. Work at this level may be performed without direct supervision but may require some limited supervision of other members of the team.

The fire sector is those sections of government departments, statutory authorities or organisations that have responsibility under jurisdictional arrangements for the delivery of firefighting and fire management services.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

## Pre-requisite Unit

It is essential that the prerequisite units listed below are obtained prior to the issuance of this unit to individuals within the fire sector or the units contributing to the attainment of a fire qualification.

PUAFIR206 Check installed fire safety systems

## Competency Field

Fire

## Unit Sector

Fire

## Elements and Performance Criteria

### ELEMENTS

### PERFORMANCE CRITERIA

Elements describe the essential outcomes.

Performance criteria describe the performance needed to demonstrate achievement of the element.

- |  |   |
|--|---|
| <b>1 Locate installed fire safety system and any associated controls and panels</b>  | <p><b>1.1</b> Installed fire safety system is located for pre-fire planning, inspection, reports and/or onsite cues</p> <p><b>1.2</b> Installed fire safety system's control and indicating panel is located and monitored, in accordance with organisational procedures, to facilitate use in supporting firefighting operations</p>   |
| <b>2 Utilise installed fire safety system to maximise effectiveness of firefighting operations and occupant evacuation</b> | <p><b>2.1</b> Installed fire safety system is used, in accordance with organisational procedures, to facilitate locating the fire, supporting occupant evacuation, undertaking rescue operations, performing fire suppression and minimising damage</p> <p><b>2.2</b> Any fault with the installed fire safety system is reported, in accordance with organisational procedures</p> |
| <b>3 Apply emergency plans and/or procedures</b>   | <p><b>3.1</b> Building emergency procedures and response structures are identified and implemented, in accordance with organisational procedures</p> <p><b>3.2</b> Fire warden and/or facility manager is consulted, in accordance with organisational procedures</p> <p><b>3.3</b> Occupant warning system is operated, in consultation with building facility personnel</p>       |
| <b>4 Utilise occupant warning systems</b>  | <p><b>4.1</b> Building occupant warning systems are effectively operated, in accordance with organisational procedures</p> <p><b>4.2</b> Any faults with the system are reported, in accordance with organisational procedures</p>  |
| <b>5 Reinstate installed fire safety system to service</b>   | <p><b>5.1</b> System is reinstated or isolated, in accordance with organisational procedures</p> <p><b>5.2</b> Any faults with the system are reported, in accordance with organisational procedures</p>  |

## Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

## Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the Companion Volume Implementation Guide.

fire safety system must include three or more of the following

- alternative fire suppression system
- fire detection system
- fire hydrant and hydrant booster system
- fire indicator panels, occupant warning and communication systems
- fire sprinklers and sprinkler booster system
- smoke hazard management and ancillary system
- systems for evacuation

## Unit Mapping Information

This unit replaces and is equivalent to PUAFIR314B Utilise installed fire safety systems.

## Links

PUA Training Package Companion Volume Implementation Guide is found in VETNet - <https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=3eca5672-6d5a-410b-8942-810d0ba05bbf>