



Australian Government

**UEEEL0012 Install low voltage wiring,
appliances, switchgear and associated
accessories**

Release: 2

UEEEL0012 Install low voltage wiring, appliances, switchgear and associated accessories

Modification History

Release 2. This is the second release of this unit of competency in the UEE Electrotechnology Training Package.

Workplace evidence requirements updated in Performance Evidence and Assessment Conditions.
Assessor requirements updated in Assessment Conditions.

Release 1. This is the first release of this unit of competency in the UEE Electrotechnology Training Package.

Application

This unit includes the installation of wiring enclosures, cable support systems, cables, protection devices, switchgear, control gear, switchboards, and accessories designed to operate at voltages up to 1,000 volt (V) alternating current (a.c.) or 1,500 V direct current (d.c.).

It covers working safely and to installation standards, routing cables to specified locations, terminating cables and connecting wiring at accessories, matching appliances and accessories with that specified, making required circuit connections and completing the necessary installation documentation.

The skills and knowledge described in this unit require a licence or permit to practice in the workplace where work is carried out on electrical installations which are designed to operate at voltages greater than 50 V a.c. or 120 V d.c.

Competency development activities in this unit are subject to regulations directly related to licensing. Where a licence or permit to practice is not held, a relevant contract of training, such as an Australian Apprenticeship, may be required.

Additional and/or other conditions may apply in some jurisdictions subject to regulations related to electrical work. Practice in the workplace and during training is also subject to work health and safety (WHS)/occupational health and safety (OHS) regulations.

Pre-requisite Unit

UEECD0007 Apply work health and safety regulations, codes and practices in the workplace

UEECD0019 Fabricate, assemble and dismantle utilities industry components

UEECD0020 Fix and secure electrotechnology equipment

UEECD0051 Use drawings, diagrams, schedules, standards, codes and specifications

UEECD0016 Document and apply measures to control WHS risks associated with electrotechnology work

UEEEL0003 Arrange circuits, control and protection for electrical installations
 UEEEL0020 Solve problems in low voltage a.c. circuits
 UEEEL0023 Terminate cables, cords and accessories for low voltage circuits
 UEEEL0018 Select wiring systems and select cables for low voltage electrical installations
 UEEEL0005 Develop and connect electrical control circuits
 UEEEL0019 Solve problems in direct current (d.c.) machines
 UEEEL0021 Solve problems in magnetic and electromagnetic devices
 UEEEL0014 Isolate, test and troubleshoot low voltage electrical circuits
 UEEEL0008 Evaluate and modify low voltage heating equipment and controls
 UEEEL0009 Evaluate and modify low voltage lighting circuits, equipment and controls
 UEEEL0010 Evaluate and modify low voltage socket outlets circuits
 UEEEL0024 Test and connect alternating current (a.c.) rotating machines
 UEEEL0025 Test and connect transformers
 and
 UEECD0043 Solve problems in direct current circuits
 or
 UEECD0044 Solve problems in multiple path circuits
 UEECD0046 Solve problems in single path circuits

Competency Field

Electrical

Unit Sector

Electrotechnology

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Prepare to install low voltage (LV) wiring, appliances, switchgear and associated accessories

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

1.1 Nature and location of work is determined from workplace documentation, drawings or relevant person/s to determine the scope of work

- 1.2 WHS/OHS requirements and workplace procedures are applied
- 1.3 Risks are identified and control measures implemented in accordance with workplace procedures
- 1.4 Need to test or measure live work is determined in accordance with WHS/OHS requirements and conducted in accordance with workplace safety procedures
- 1.5 Circuits/machines/plant are checked as being isolated, where necessary, in strict accordance with WHS/OHS requirements and procedures.
- 1.6 Installation of wiring, appliances, switchgear, control gear and associated accessories is planned and appropriately sequenced in consultation with relevant person/s
- 1.7 Locations of appliances, switchgear, accessories and cable routes are planned within the constraints of building structure, other services, specifications and regulatory requirements
- 1.8 Material required for installation work is obtained in accordance with workplace procedures and checked against job specifications
- 1.9 Tools, equipment and measuring devices required for the installation and work environment are obtained in accordance with workplace procedures and checked for correct operation and safety
- 1.10 Preparatory work is inspected and checked to ensure no damage has occurred and compliance with job specifications

2 Install LV wiring and associated accessories

- 2.1 Wiring and accessories are installed and terminated to comply with technical standards and job specifications and requirements
 - 2.2 Accessories are installed straight and square in the required locations and within acceptable tolerances
 - 2.3 Cables and conductors are terminated at accessories in accordance with manufacturer specifications and regulatory requirements
-

- 2.4 Ongoing compliance and safety inspection of installed wiring systems and testing of installed circuits is undertaken
 - 2.5 Defects revealed through on-going compliance and safety inspection and tests are rectified
 - 2.6 Cable installation and termination is carried out efficiently without unnecessary waste of materials or damage to apparatus, circuits, the surrounding environment using sustainable energy practices
 - 2.7 Unexpected situations are dealt with safely and with the approval of an authorised person
- 3 Install and connect LV appliances, switchgear and associated accessories**
- 3.1 Appliances, switchgear and accessories are installed to comply with technical standards and job specifications and requirements with sufficient access to affect terminations, adjustment and maintenance
 - 3.2 Accessories are installed straight and square in the required locations and within acceptable tolerances
 - 3.3 Wiring is terminated at appliances, switchgear and accessories in accordance with manufacturer specifications and functional and regulatory requirements
 - 3.4 Ongoing compliance and safety inspections of the installed appliances, switchgear and accessories are undertaken
 - 3.5 Defects revealed through on-going compliance and safety inspection are rectified
 - 3.6 Installation is carried out efficiently without unnecessary waste of materials or damage to apparatus, circuits, the surrounding environment or services using sustainable energy principles
 - 3.7 Unexpected situations are dealt with safely and with the approval of an authorised person
- 4 Complete work and document activities**
- 4.1 WHS/OHS work completion risk control measures and procedures are followed
 - 4.2 Worksite is cleaned and made safe in accordance with workplace procedures
-

- 4.3 'As-installed' cables/wiring, appliances, switchgear and accessories are documented and an appropriate person/s notified in accordance with workplace procedures

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the UEE Electrotechnology Training Package Companion Volume Implementation Guide.

Installing LV wiring, appliances, switchgear and associate accessories must include:

- installing and connecting main switches, protective devices and links on a main switchboard and preparing the switchboard for the installation of metering
- installing, modifying and testing electrical installations and equipment for construction and demolition sites
- installing and connecting a switchboard
- socket outlets
- lighting equipment and accessories
- luminaires

Installing LV wiring, appliances, switchgear and associate accessories must also include least four of the following:

- cooking appliances
- smoke and fire detectors
- water heaters and controls
- three phase motor starter and control switches
- fixed electric heating system (room heaters)
- transformers
- appliances producing hot water or steam
- electric heating cables for floors and ceilings
- trace heating
- duct heaters
- electricity converters
- capacitors
- batteries
- gas appliances and equipment
- air conditioning and heat pump systems
- lifts

Wiring systems, enclosures

- metallic conduit
-

and supports must include at least three of the following:

- non-metallic conduit
- trunking
- duct
- cable tray/ladder
- catenary
- posts/poles/struts

Cable types used for wiring systems must include at least four of the following:

- thermoplastic insulated (TPI) cable
- flat thermoplastic sheathed (TPS)
- circular TPS
- steel wire armoured
- fire rated cable
- flexible cables

Purpose of wiring system circuits must include:

- consumer mains
- sub-mains
- single phase final sub-circuit
- three phase final sub-circuit

Unit Mapping Information

No equivalent unit

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=b8a8f136-5421-4ce1-92e0-2b50341431b6>
