



Australian Government

**UEERA0032 Diagnose and rectify faults in
complex air conditioning/refrigeration
systems**

Release: 1

UEERA0032 Diagnose and rectify faults in complex air conditioning/refrigeration systems

Modification History

Release 1. This is the first release of this unit of competency in the UEE Electrotechnology Training Package.

Application

This unit involves the skills and knowledge required to diagnose and rectify faults in complex air conditioning/refrigeration systems.

It includes working safely, interpreting technical data and applying knowledge of complex refrigeration/air conditioning system operating parameters to logical fault-finding processes. It also includes implementing fault rectification, safety and functional testing, and completing and reporting fault diagnosis and rectification activities and outcomes.

To undertake this unit, the learner must have a Trainee Refrigerant Handling Licence as it includes work on refrigeration and air conditioning equipment that carries the risk of a fluorocarbon refrigerant being emitted.

The skills and knowledge described in this unit require a national Refrigerant Handling Licence as it includes work on refrigeration and air conditioning equipment that carries the risk of a fluorocarbon refrigerant being emitted while decanting the refrigerant or manufacturing, installing, commissioning, servicing, maintaining or decommissioning refrigeration and air conditioning equipment.

The skills and knowledge described in this unit require a licence or permit to practice in the workplace where work is carried out on electrical installations which are designed to operate at voltages greater than 50 volt (V) alternating current (a.c.) or 120 V direct current (d.c.).

Competency development activities in this unit are subject to regulations directly related to licensing. Where a licence or permit to practice is not held, skills and knowledge described in this unit require a relevant contract of training, such as an Australian Apprenticeship.

Additional and/or other conditions may apply in some jurisdictions subject to regulations related to refrigeration, air conditioning or electrical work. Practice in the workplace and during training is also subject to work health and safety (WHS)/occupational health and safety (OHS) regulations.

Permits may also be required for some work environments, such as confined spaces, working aloft, near live electrical apparatus and site rehabilitation.

Pre-requisite Unit

UEECD0007 Apply work health and safety regulations, codes and practices in the workplace

UEECD0019 Fabricate, assemble and dismantle utilities industry components

UEECD0020 Fix and secure electrotechnology equipment

UEECD0051 Use drawings, diagrams, schedules, standards, codes and specifications

UEECD0016 Document and apply measures to control WHS risks associated with electrotechnology work

UEERA0059 Prepare and connect refrigerant tubing and fittings

UEERA0036 Establish the basic operating conditions of vapour compression systems

UEERA0035 Establish the basic operating conditions of air conditioning systems

UEERA0050 Install refrigerant pipe work, flow controls and accessories

UEERA0094 Verify functionality and compliance of refrigeration and air conditioning installations

UEERA0081 Select refrigerant piping, accessories and associated controls

UEERA0031 Diagnose and rectify faults in air conditioning and refrigeration control systems

UEERA0092 Solve problems in low voltage refrigeration and air conditioning circuits

UEERL0005 Locate and rectify faults in low voltage (LV) electrical equipment using set procedures

UEERL0004 Disconnect - reconnect electrical equipment connected to low voltage (LV) installation wiring

UEERL0001 Attach cords and plugs to electrical equipment for connection to a single phase 230 Volt supply

UEERL0002 Attach cords, cables and plugs to electrical equipment for connection to 1000 V a.c. or 1500 V d.c.

Competency Field

Refrigeration and air-conditioning

Unit Sector

Electrotechnology

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Prepare to diagnose and rectify faults

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

1.1 WHS/OHS requirements and procedures are identified, obtained and implemented

- 1.2 WHS/OHS risk control measures and procedures are followed in preparation for work
 - 1.3 Hazards are monitored and any not previously identified are documented and risk control measures implemented in consultation with relevant person/s
 - 1.4 The extent of faults are determined from reports/documentation and discussions with relevant person/s
 - 1.5 Relevant person/s is consulted to ensure work is coordinated with others on the worksite
 - 1.6 Tools, equipment and testing devices required to diagnose faults are obtained and checked for correct operation and safety in accordance with workplace procedures
- 2 Diagnose and rectify faults**
- 2.1 WHS/OHS risk control measures and workplace procedures for carrying out the work are followed
 - 2.2 Need to test or measure live work is determined in accordance with workplace procedures and WHS/OHS requirements
 - 2.3 Circuits/machines/plant are checked as being isolated, where necessary, in accordance with workplace procedures and WHS/OHS requirements
 - 2.4 Logical diagnostic methods, measurements and estimations are applied to diagnose complex refrigeration/air conditioning system faults in accordance with system operational parameters and requirements
 - 2.5 Suspected fault sources are tested to confirm if they are the source of system problems
 - 2.6 Fault causes are identified and appropriately competent person/s engaged to rectify the fault where it is outside the scope of the refrigeration and air conditioning system
 - 2.7 Faults in system components are rectified to return refrigeration/air conditioning system to its operational standard
 - 2.8 System is tested to verify that the system operates as

intended and to specified requirements and industry standards

- 2.9 Methods for resolving unexpected situations are discussed, as required, with appropriate person/s in accordance with job specifications and requirements
- 2.10 Methods for resolving unexpected situations are selected on the basis of safety and specified work outcomes
- 2.11 Diagnosis and rectification activities are conducted without waste of materials, damage to apparatus, the surrounding environment and/or services using sustainable energy practices

3 Complete and report fault diagnosis and rectification activities

- 3.1 WHS/OHS work completion risk control measures and procedures are followed
- 3.2 Worksite is made safe in accordance with workplace safety procedures
- 3.3 Fault diagnosis and rectification activities are documented in accordance with workplace procedures
- 3.4 Appropriate person/s is notified that system faults have been rectified in accordance with workplace procedures

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the UEE Electrotechnology Training Package Companion Volume Implementation Guide.

Diagnosing and rectifying faults must include at least four faults in the following complex refrigeration/air conditioning systems:

- multiple major components (i.e. compressors, condenser or evaporators)
- circuits or systems and associated components and controls

Unit Mapping Information

This unit replaces and is equivalent to UEENEEJ112A Diagnose and rectify faults in complex air conditioning/refrigeration systems.

Links

Companion Volume implementation guides are found in VETNet - -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=b8a8f136-5421-4ce1-92e0-2b50341431b6>