

# UEERA0048 Install and commission flammable refrigerant air conditioning and refrigeration systems

Release: 1

# UEERA0048 Install and commission flammable refrigerant air conditioning and refrigeration systems

# **Modification History**

Release 1. This is the first release of this unit of competency in the UEE Electrotechnology Training Package.

# **Application**

This unit involves the skills and knowledge required to install and commission Class A2, A2L and A3 flammable refrigerant air conditioning and refrigeration systems, components and associated equipment in accordance with legislative, standard and code requirements. It includes working safely and installing equipment, components and piping to job specifications. It also includes completing pre-commissioning tests, starting the system, ensuring correct refrigerant charge, adjusting components and controls to efficient operation, completing installation and commissioning documentation.

Some flammable refrigerants, for example, fluorocarbons like R32, are controlled under the national Ozone Protection and Synthetic Greenhouse Gas Management Regulations 1995. Therefore, to undertake this unit, the learner must have a relevant Trainee Refrigerant Handling Licence if it includes work on refrigeration and air conditioning equipment that carries the risk of a fluorocarbon refrigerant being emitted.

The skills and knowledge described in this unit require a national Refrigerant Handling Licence if it includes work on refrigeration and air conditioning equipment that carries the risk of a fluorocarbon refrigerant being emitted while decanting the refrigerant or manufacturing, installing, commissioning, servicing, maintaining or decommissioning refrigeration and air conditioning equipment.

The skills and knowledge described in this unit require a licence or permit to practice in the workplace where work is carried out on electrical installations which are designed to operate at voltages greater than 50 volt (V) alternating current (a.c.) or 120 V direct current (d.c.).

Competency development activities in this unit are subject to regulations directly related to licensing. Where a licence or permit to practice is not held, skills and knowledge described in this unit require a relevant contract of training, such as an Australian Apprenticeship.

Additional and/or other conditions may apply in some jurisdictions subject to regulations related to refrigeration, air conditioning or electrical work. Practice in the workplace and during training is also subject to work health and safety (WHS)/occupational health and safety (OHS) regulations.

Permits may also be required for some work environments, such as confined spaces, working aloft, near live electrical apparatus and site rehabilitation.

Approved Page 2 of 6

### **Pre-requisite Unit**

UEERA0007 Apply safety awareness and legal requirements for flammable refrigerants UEERA0053 Install, commission, service and maintain medium temperature systems

# **Competency Field**

Refrigeration and air-conditioning

#### **Unit Sector**

Electrotechnology

#### **Elements and Performance Criteria**

#### **ELEMENTS**

#### PERFORMANCE CRITERIA

Elements describe the essential outcomes.

Performance criteria describe the performance needed to demonstrate achievement of the element.

- 1 Prepare to install and commission flammable refrigerant refrigeration and air conditioning systems
- **1.1** WHS/OHS hazards, risk control methods, relevant standards, codes and legislation are obtained and applied
- **1.2** Safety hazards not previously identified are noted and risk control measures implemented
- **1.3** Scope of work is determined from documentation and/or relevant person/s to establish work to be undertaken
- **1.4** Component, equipment installation and commissioning work are sequenced in accordance with job schedule
- **1.5** Relevant person/s is consulted to ensure the work is coordinated with others involved
- **1.6** Materials required to install pipe work are obtained in accordance with workplace procedures and job specifications
- 1.7 Tools, equipment and testing devices required to install and commission components and equipment are obtained in accordance with workplace procedures and checked for correct operation and safety

Approved Page 3 of 6

- **1.8** System control settings and operating parameters are determined from job specifications
- 1.9 Preparatory work is scheduled to ensure no damage has occurred in accordance with workplace procedures and relevant industry standards
- 2 Install flammable refrigerant refrigeration and air conditioning systems
- 2.1 Circuits/machines/plant are checked and isolated in accordance with WHS/OHS requirements and workplace procedures
- 2.2 Components and equipment are installed with sufficient access to affect electrical and pipe work connections and maintenance in accordance with relevant legislation, standards and code requirements, manufacturer instructions, job specifications and workplace procedures
- 2.3 Components and equipment are installed in the required locations and within acceptable tolerances in accordance with relevant legislation, standards and code requirements, manufacturer instructions, job specifications and workplace procedures
- 2.4 Refrigerant tubing and fittings are silver brazed with dry nitrogen to prevent contamination in accordance with relevant legislation, standards and code requirements, manufacturer instructions, job specifications and workplace procedures
- 2.5 Unplanned situations from installation of components and equipment are dealt with in accordance with workplace procedures
- Quality checks of pipe work, pressure testing and repair of leaks are conducted in accordance with relevant legislation, standard and code requirements, manufacturer instructions, job specifications and workplace procedures
- 2.7 Components and equipment are installed efficiently without waste of materials or damage/contamination to apparatus, the surrounding environment or services using sustainable energy practices
- 3 Commission flammable refrigerant refrigeration and air conditioning
- 3.1 Installed system's pipe work and components are evacuated to the required level in accordance with relevant legislation, standards and code requirements

Approved Page 4 of 6

#### systems

#### and manufacturer instruction

- 3.2 System is charged with flammable refrigerant to the required level in accordance with relevant legislation, standard and code requirements, manufacturer instructions and job specification
- 3.3 Refrigeration system pressure controls, valves and regulators are adjusted in accordance with relevant legislation, standard and code requirements, manufacturer instructions, job specifications and workplace procedures
- 3.4 Testing/measuring devices are used to observe operation of the refrigeration system and fine adjustments of controls made, as required, in accordance with relevant legislation, standard and code requirements, manufacturer instructions, job specifications and workplace procedures
- 3.5 Unplanned situations are dealt with safely and with the approval of relevant person/s
- 3.6 Commissioning is conducted efficiently without waste of materials or damage to apparatus, the surrounding environment or services using sustainable energy practices
- 4 Complete installation and commissioning work
- **4.1** Worksite is cleaned and made safe in accordance with workplace procedures
- **4.2** Final check of the installed components and equipment is made in accordance with relevant industry standards and job specifications
- 4.3 'As installed' components and equipment are documented and relevant person/s notified in accordance with workplace procedures
- **4.4** Results of commissioning and final operating parameters are documented and relevant person/s notified in accordance with workplace procedures

#### **Foundation Skills**

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Approved Page 5 of 6

## **Range of Conditions**

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the UEE Electrotechnology Training Package Companion Volume Implementation Guide.

Installing and commissioning major components and associated equipment must include at least the following:

two refrigeration and/or air conditioning systems operating with a flammable refrigerants refrigerant

Major components must include at least the following:

Associated equipment must include at least the

- refrigeration compressors
- condensers
- condensing units
- evaporators
- refrigerant flow controls
- cycling controls
- safety controls
- on-site leak detection equipment
- ventilation systems
- spark isolation systems and electrical isolation
- monitoring equipment
- inspection accessories

# **Unit Mapping Information**

This unit replaces and is equivalent to UEENEEJ176A Install and commission hydrocarbon refrigeration systems, components and associated equipment.

#### Links

following:

Companion Volume implementation guides are found in VETNet -https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=b8a8f136-5421-4ce1-92e0-2b50341431b6

Approved Page 6 of 6 Australian Industry Standards