



Australian Government

**Assessment Requirements for UEERE0008
Conduct periodic maintenance of remote
area power supply photovoltaic arrays**

Release: 2

Assessment Requirements for UEERE0008 Conduct periodic maintenance of remote area power supply photovoltaic arrays

Modification History

Release 2. This minor update is the second release of this unit of competency in the UEE Electrotechnology Training Package.

Typographic error in prerequisite option requirements fixed.

Release 1. This is the first release of this unit of competency in the UEE Electrotechnology Training Package.

Performance Evidence

Evidence required to demonstrate competence in this unit must be relevant to and satisfy all of the requirements of the elements, performance criteria and range of conditions on at least one occasion and include:

- measuring and recording array no-load and load voltages together with ambient temperature
- measuring and recording array output for three load conditions
- visually inspecting array modules and support structure for physical damage
- visually inspecting array connections and cables
- identifying array defects and faults
- reporting all maintenance activities
- dealing with unplanned events
- applying relevant work health and safety (WHS)/occupational health and safety (OHS) requirements and workplace procedures and practices, including the use of risk control measures
- checking for damage or de-lamination
- checking isolation of circuits/machines/systems
- cleaning of photovoltaic (PV) modules
- coordinating work with relevant personnel and the local community
- determining live electrical work testing/measurement requirements
- identifying and accessing materials, tools, equipment and testing devices
- maintaining remote area power supply (RAPS) PV arrays, including maintaining logbooks and maintenance regime.

Knowledge Evidence

Evidence required to demonstrate competence in this unit must be relevant to and satisfy all of the requirements of the elements, performance criteria and range of conditions and include knowledge of:

- RAPS systems PV array maintenance techniques encompassing:
 - cleaning of PV modules
 - checking for damage or de-lamination
 - checking of module connections, connecting cable and integrity of the array structure
 - maintaining logbooks and maintenance regime
- relevant RAPS system manufacturer specifications
- relevant job safety assessments or risk mitigation processes
- relevant WHS/OHS legislated requirements
- relevant workplace documentation, policies and procedures.

Assessment Conditions

Assessors must hold credentials specified within the Standards for Registered Training Organisations current at the time of assessment.

Assessment must satisfy the Principles of Assessment and Rules of Evidence and all regulatory requirements included within the Standards for Registered Training Organisations current at the time of assessment.

Assessment must occur in suitable workplace operational situations where it is appropriate to do so; where this is not appropriate, assessment must occur in suitable simulated workplace operational situations that replicate workplace conditions.

Assessment processes and techniques must be appropriate to the language, literacy and numeracy requirements of the work being performed and the needs of the candidate.

Resources for assessment must include access to:

- a range of relevant exercises, case studies and/or other simulations
- relevant and appropriate materials, tools, equipment and personal protective equipment (PPE) currently used in industry
- resources that reflect current industry practice in relation to conducting periodic maintenance of RAPS PV array
- applicable documentation, including workplace procedures, equipment specifications, regulations, codes of practice and operation manuals.

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=b8a8f136-5421-4ce1-92e0-2b50341431b6>