



**Australian Government**

**Department of Education, Employment and Workplace Relations**

# **UEENEEG071C Install and set up interval metering**

**Release: 1**

## UEENEEG071C Install and set up interval metering

### Modification History

Not Applicable

### Unit Descriptor

#### Unit Descriptor

1)

#### 1.1) Descriptor

This unit covers the installation and set up of interval metering for measurement of energy use by consumers under choice of supplier arrangement. It encompasses working safely and to installation and set up standards, evaluating the integrity of metering wiring and earthing systems, fixing metering, making power and communication connections, setting meter parameters and completing the necessary documentation.

### Application of the Unit

#### Application of the Unit 4)

This unit is intended as an additional competency to relevant competencies previously acquired. It is suitable for employment-based programs under an approved contract of training at the aligned AQF 3 level or higher.

- license to practice in the workplace subject to regulations for undertaking of electrical work, and
- 

Practice in workplace and during training is also subject to regulations directly related to occupational health and safety and where applicable contracts of training such as apprenticeships.

Note:

1. Compliance with permits may be required in various jurisdictions and typically relates to the operation of plant, machinery and equipment such as elevating work platforms, powder operated fixing tools, power operated tools, vehicles, road signage and traffic control and lifting

**Application of the Unit 4)**

equipment. Permits may also be required for some work environments such as confined spaces, working aloft, near live electrical apparatus and site rehabilitation.

2. Compliance may be required in various jurisdictions relating to currency in First Aid, confined space, lifting and risk safety measures.

**Licensing/Regulatory Information****1.2) License to practice**

The skills and knowledge described in this unit require a license to practice in the workplace subject to regulations for undertaking of electrical work. Practice in workplace and during training is also subject to regulations directly related to occupational health and safety and where applicable contracts of training such as apprenticeships.

**Pre-Requisites****Prerequisite Unit(s) 2)****2.1) Competencies**

Granting competency in this unit shall be made only after competency in the following unit(s) has/have been confirmed.

UEENEEG005B Verify compliance and functionality of general electrical installations

For the full prerequisite chain details for this unit please refer to Table 2 in Volume 1, Part 2

## Employability Skills Information

### Employability Skills 3)

This unit contains Employability Skills

The required outcomes described in this unit of competency contain applicable facets of Employability Skills. The Employability Skills Summary of the qualification in which this unit of competency is packaged will assist in identifying Employability Skill requirements.

## Elements and Performance Criteria Pre-Content

6) Elements describe the essential outcomes of a unit of competency	Performance criteria describe the required performance needed to demonstrate achievement of the Element. Assessment of performance is to be consistent with the evidence guide.
---	---

## Elements and Performance Criteria

ELEMENT	PERFORMANCE CRITERIA
1 Prepare to install and set up interval metering.	1.1 OHS procedures for a given work area are identified, obtained and understood.
	1.2 Health and safety risks are identified and established risk control measures and procedures in preparation for the work are followed.
	1.3 Safety hazards that have not previously been identified are noted and established risk control measures are implemented. (Note 1.)
	1.4 Switchboard on which the meter is to be installed is inspected and evaluated for compliance with safety and functionality standards. (Note 2)
	1.5 Approval to rectify safety and/or functionality defects of the switchboard is sought from person

<b>ELEMENT</b>	<b>PERFORMANCE CRITERIA</b>
	of higher authority in accordance with established procedures.
	1.6 Installation of the meter and rectification work is prepared in consultation with other effected by the work and sequenced appropriately. (Note 3)
	1.7 Material needed for the work is obtained in accordance with established procedures and checked against job requirements.
	1.8 Tools, equipment and testing devices needed to for the work are obtained in accordance with established procedures and checked for correct operation and safety.
2 Install and set up interval metering.	2.1 OHS risk control measures and procedures for carrying out the work are followed.
	2.2 The need to test or measure live is determined in strict accordance with OHS requirements and when necessary conducted within established safety procedures.
	2.3 Existing metering is checked as being isolated in strict accordance OHS requirements and procedures.
	2.4 Approved rectification work is carried out to comply with standards and in accordance with established procedures.
	2.5 Metering is installed to comply with technical standards and job specifications and requirements.
	2.6 Metering power and communication connections are made in accordance with manufacture's specifications and functional and regulatory requirements.
	2.7 Meter operating parameters are set in accordance with manufacture's specifications and functional and regulatory requirements.
	2.8 Unexpected situations are dealt with safely and with the approval of an authorised person

ELEMENT	PERFORMANCE CRITERIA
	<p>2.9 Ongoing checks of the quality of installed apparatus are undertaken in accordance with established procedures.</p> <p>2.10 Metering installation is carried out efficiently without unnecessary waste of materials or damage to apparatus, circuits, the surrounding environment or services and using sustainable energy principles.</p>
3 Completion and report metering installation activities.	<p>3.1 OHS work completion risk control measures and procedures are followed and supply is reinstated to the installation.</p> <p>3.2 Work site is cleaned and made safe in accordance with established procedures.</p> <p>3.3 Final checks are made to that the installed metering conforms to requirements.</p> <p>3.4 'As-installed' metering and rectification work is documented and appropriate persons notified in accordance with established procedures.</p>

Note.

1. Examples of hazards likely to be encountered are asbestos reinforced switchboard panels, deteriorating switchgear and cabling and location of the switchboard.
2. Safety and functionality standards include the clear identification of switchboard components and their function, sound electrical insulation of wiring and components, sound MEN and main earth connections, fire integrity and access.
3. Preparation includes arranging for the safe isolation of the installation, access to a telecommunications connection where two-way metering is to be installed and access to a transducer connection where gas metering is to be included.

## Required Skills and Knowledge

### REQUIRED SKILLS AND KNOWLEDGE

7) This describes the essential skills and knowledge and their level, required for this unit.

Evidence shall show that knowledge has been acquired of safe working practices and installing and setting up interval metering.

## **REQUIRED SKILLS AND KNOWLEDGE**

All knowledge and skills detailed in this unit should be contextualised to current industry practices and technologies.

The extent of the essential knowledge and associated skills (EKAS) required is given in Volume 2 - Part 2.2 EKAS. It forms an integral part of this unit.

- 2.5.2.1 Technical standards, regulations and codes for general electrical installations
- 2.5.12 Electricity distributors, supply requirements
- 2.6.2.2 Electrical metering arrangements
- 2.6.2.3 Interval metering concepts and applications
- 2.18.1 Occupational Health and Safety Principles
- 2.18.2 Electrical safe working practices

## Evidence Guide

### EVIDENCE GUIDE

9) The evidence guide provides advice on assessment and must be read in conjunction with the Performance Criteria, Required Skills and Knowledge, the Range Statement and the Assessment Guidelines for this Training Package.

The Evidence Guide forms an integral part of this unit. It must be used in conjunction with all parts of this unit and performed in accordance with the Assessment Guidelines of this Training Package.

#### Overview of Assessment

##### 9.1)

Longitudinal competency development approaches to assessment, such as Profiling, require data to be reliably gathered in a form that can be consistently interpreted over time. This approach is best utilised in Apprenticeship programs and reduces assessment intervention. It is the Industry's preferred model for apprenticeships. However, where summative (or final) assessment is used it is to include the application of the competency in the normal work environment or, at a minimum, the application of the competency in a realistically simulated work environment. It is recognised that, in some circumstances, assessment in part or full can occur outside the workplace. However, it must be in accordance with industry and regulatory policy.

Methods chosen for a particular assessment will be influenced by various factors. These include the extent of the assessment, the most effective locations for the assessment activities to take place, access to physical resources, additional safety measures that may be required and the critical nature of the competencies being assessed.

The critical safety nature of working with electricity, electrical equipment, gas or any other hazardous substance/material carries risk in deeming a person competent. Sources of evidence need to be 'rich' in nature to minimise error in judgment.

Activities associated with normal every day work have a bearing on the decision as to how much and how detailed the data gathered will contribute to its 'richness'. Some skills are more critical to safety and operational requirements while the same skills may be more or less frequently practised. These points are raised for the assessors to consider when choosing an assessment method and developing assessment instruments. Sample assessment instruments are included for Assessors in



## EVIDENCE GUIDE

the Assessment Guidelines of this Training Package.

### Critical aspects of evidence required to demonstrate competency in this unit

#### 9.2)

Before the critical aspects of evidence are considered all prerequisites shall be met.

Evidence for competence in this unit shall be considered holistically. Each element and associated performance criteria shall be demonstrated on at least two occasions in accordance with the 'Assessment Guidelines - UEE07'. Evidence shall also comprise:

- A representative body of work performance demonstrated within the timeframes typically expected of the discipline, work function and industrial environment. In particular this shall incorporate evidence that shows a candidate is able to:
  - Implement Occupational Health and Safety workplace procedures and practices including the use of risk control measures as specified in the performance criteria and range statement
  - Apply sustainable energy principles and practices as specified in the performance criteria and range statement
  - Demonstrate an understanding of the essential knowledge and associated skills as described in this unit
    - It may be required by some jurisdictions that RTOs provide a percentile graded result for the purpose of regulatory or licensing requirements.
  - Demonstrate an appropriate level of skills enabling employment
  - Conduct work observing the relevant Anti Discrimination legislation, regulations, polices and workplace procedures
- Demonstrated consistent performance across a representative range of contexts from the prescribed items below:
  - Install and set up interval metering as described in 8) and including:
    - A Inspecting and evaluating safety and functionality compliance of the switchboard accurately.
    - B Following established procedures to obtain approval to rectify non-compliance aspects of the switchboard.

## EVIDENCE GUIDE

- C Carrying out preparation work effectively.
- D Rectifying compliance defects.
- E Placing and securing metering correctly.
- F Making power and communications connections in accordance with manufacture's specifications and functional and regulatory requirements.
- G Setting meter parameters in accordance with manufacture's specifications and functional and regulatory requirements.
- H Reinstating supply to the installation safely.
- I Documenting metering and rectification work and notifying appropriate persons in accordance with established procedures.
- J Dealing with unplanned events by drawing on essential knowledge and skills to provide appropriate solutions incorporated in the holistic assessment with the above listed items.

### Context of and specific resources for assessment

#### 9.3)

This unit should be assessed as it relates to normal work practice using procedures, information and resources typical of a workplace. This should include:

- OHS policy and work procedures and instructions.
- Suitable work environment, facilities, equipment and materials to undertake actual work as prescribed by this unit.

Resources required to assess this unit are listed above in 'Context of assessment', which should also be used in the formal learning/assessment environment.

Note:

Where simulation is considered a suitable strategy for assessment, conditions must be authentic and as far as possible reproduce and replicate the workplace and be consistent with the approved industry simulation policy.

The resources used for assessment should reflect current industry practices in relation to installing and setting up interval

**EVIDENCE GUIDE**

metering.

**Method of  
assessment****9.4)**

This unit shall be assessed by methods given in Volume 1, Part 3 'Assessment Guidelines'.

**Note:**

Competent performance with inherent safe working practices is expected in the industry to which this unit applies. This requires assessment in a structured environment which is primarily intended for learning/assessment and incorporates all necessary equipment and facilities for learners to develop and demonstrate the essential knowledge and skills described in this unit.

**Concurrent  
assessment and  
relationship with  
other units****9.5)**

There are no concurrent assessment recommendations for this unit.

The critical aspects of occupational health and safety covered in unit UEENEEE001B and other discipline specific occupational health and safety units shall be incorporated in relation to this unit..

## Range Statement

### RANGE STATEMENT

8) This relates to the unit as a whole providing the range of contexts and conditions to which the performance criteria apply. It allows for different work environments and situations that will affect performance.

This unit shall be demonstrated in relation to the installation of at least:

- a single phase interval meter
- a two-way interval meter
- an interval meter where compliance rectification work is required

Generic terms used throughout this Vocational Standard shall be regarded as part of the Range Statement in which competency is demonstrated. The definition of these and other terms that apply are given in Volume 2, Part 2.1.

## Unit Sector(s)

Not Applicable

## Competency Field

### 2.2) Literacy and numeracy skills

Participants are best equipped to achieve competency in this unit if they have reading, writing and numeracy skills indicated by the following scales. Description of each scale is given in Volume 2, Part 3 'Literacy and Numeracy'

Reading	5	Writing	5	Numeracy	5
---------	---	---------	---	----------	---

## Custom Content Section

Competency Field 5)

Electrical

