



Australian Government

UEGNSG052 Establish a utilities infrastructure worksite

Release: 1

UEGNSG052 Establish a utilities infrastructure worksite

Modification History

Release 1. This is the first release of this unit of competency in the UEG Gas Industry Training Package.

Application

This unit involves the skills and knowledge required to establish utilities infrastructure worksites.

It includes planning and scheduling work; organising resources, materials, procedures and the site for required utilities work activities in accordance with relevant legislation, industry standards, codes of practice and workplace procedures; and completing work and relevant documentation.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

Pre-requisite Unit

Not applicable.

Competency Field

Gas Cross Discipline

Unit Sector

Gas Industry

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Prepare to establish a utilities worksite

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

- 1.1** Workplace safety, environmental and sustainable energy practices for the site are identified, obtained and understood
- 1.2** Job requirements are obtained and interpreted from plans, specifications and instructions

- 1.3 Relevant job requirements and workplace procedures for work activities are discussed with relevant person/s, including third parties, to determine and confirm work schedule and respective responsibilities
 - 1.4 Hazards are identified, workplace safety and environmental risks are assessed, and control measures are prioritised, implemented and monitored in accordance with workplace procedures
 - 1.5 Scope of responsibility under the relevant job requirements, including all work permits and/or relevant notifications, is determined and confirmed to access the services and perform work in accordance with job requirements and workplace procedures
 - 1.6 Equipment, tools and personal protective equipment (PPE) needed to carry out work activities are identified, obtained and checked for correct operation and safety in accordance with workplace procedures and manufacturer instructions
 - 1.7 Materials, plans, diagrams, drawings and resources required for work are confirmed and obtained in accordance with workplace procedures
- 2 Establish a utilities worksite**
- 2.1 Workplace safety and environmental risk control measures, schedule of work and workplace procedures for carrying out work are followed
 - 2.2 Appropriate materials, tools and equipment are selected and used safely in accordance with manufacturer instructions and workplace procedures
 - 2.3 Work is completed within agreed timeframe and to industry standards in accordance with job requirements and workplace procedures
 - 2.4 Hazardous activities are conducted safely in accordance with regulatory requirements and workplace procedures
 - 2.5 Alarms, codes, and hazard warnings are correctly recognised, and the correct response strategy is selected and applied in accordance with workplace procedures
 - 2.6 Faults and operational conditions of the components are identified, repaired or replaced, and reported in accordance with organisational job requirements

- | | | |
|---|-----|--|
| | 2.7 | Unplanned events are referred to the relevant person/s for directions in accordance with workplace procedures |
| 3 Complete work and relevant documentation | 3.1 | Workplace safety risk control measures for work completion are followed |
| | 3.2 | Quality and safety checks of the work are conducted in accordance with job requirements, workplace procedures and community and industry standards |
| | 3.3 | Worksite is cleaned, reinstated and made safe in accordance with workplace procedures |
| | 3.4 | Tools, equipment, and any surplus resources/materials are cleaned, checked and securely stored in accordance with workplace procedures |
| | 3.5 | Incidents are reported and followed up as required in accordance with workplace procedures |
| | 3.6 | Relevant person/s is notified of work completion in accordance with workplace procedures |
| | 3.7 | Work completion documentation is completed accurately and provided to relevant person/s in accordance with workplace procedures |

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the UEG Gas Industry Training Package Companion Volume Implementation Guide.

Unit Mapping Information

This unit replaces and is equivalent to UEGNSG134 Establish a utilities infrastructure work site.

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=6a6c032e-ffcb-4f3d-8063-415efbd261e8>