



Australian Government

UETDRTO010 Maintain energised transmission lines using barehand techniques from a helicopter

Release: 1

UETDRT0010 Maintain energised transmission lines using barehand techniques from a helicopter

Modification History

Release 1. This is the first release of this unit of competency in the UET Transmission, Distribution and Rail Sector Training Package Release 2.0.

Application

This unit involves the skills and knowledge required to maintain energised transmission lines using barehand techniques from a helicopter in the electricity supply industry (ESI).

It includes the calculation of physical loads and the use and maintenance of specialised tools and equipment, live work authorities/permits and disabling the automatic re-closing device.

The application of the skills and knowledge described in this unit may require a licence/registration to practice in the workplace.

Other conditions may also apply under state and territory legislative and regulatory licensing requirement which must be confirmed prior to commencing this unit.

Pre-requisite Unit

UETDRT0012 Maintain energised transmission lines using live work stick techniques

Competency Field

Transmission Overhead

Unit Sector

Not applicable.

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Prepare to maintain energised transmission

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

1.1 Legislation, regulations, standards, codes of practice and organisational workplace requirements for the work to

lines from a helicopter	be performed are referred to and confirmed
1.2	Work plan is obtained and confirmed in accordance with workplace requirements
1.3	Materials required for work are determined and obtained in accordance with work plan and workplace requirements
1.4	Tools, equipment and personal protective equipment (PPE) required for work are determined, obtained and confirmed in working order
1.5	Hazards are identified, risks assessed and control measures identified and applied
1.6	Safety observer role and responsibilities are discussed and confirmed in accordance with workplace requirements
1.7	Communication method between the workers and safety observer is determined and confirmed in accordance with workplace requirements
1.8	Minimum approach distances for the work to be performed are determined and confirmed in accordance with workplace requirements
1.9	Work is prioritised and sequenced for completion in accordance with work plan and workplace requirements
1.10	Work permits are received and signed in accordance with workplace requirements
1.11	Auto-reclose devices and associated circuits are rendered inoperative in accordance with workplace requirements
1.12	Worksite is prepared in accordance with the work plan and workplace requirements
1.13	Traffic management plan is confirmed as being in place in accordance with workplace requirements
2 Perform maintenance of energised transmission lines from a helicopter	2.1 Legislation, regulations, standards, codes of practice and organisational workplace requirements for the work to be performed are applied and monitored
	2.2 Working at heights and the use of tools, equipment and PPE are carried out in accordance with workplace requirements

- 2.3 Hazard control measures are monitored in accordance with workplace requirements
 - 2.4 Minimum approach distances are maintained when the work is being performed
 - 2.5 Energised overhead electrical transmission apparatus is maintained in accordance with the work plan and workplace requirements
 - 2.6 Incidents or unplanned events are responded to in accordance with workplace requirements
 - 2.7 Quality checks of work are undertaken in accordance with work plan and workplace requirements
- 3 Complete work and documentation**
- 3.1 Completed work is checked for compliance against the work plan and workplace requirements
 - 3.2 Incidents or unplanned events are reported in accordance with workplace requirements
 - 3.3 Worksite is rehabilitated, cleaned and made safe in accordance with workplace requirements
 - 3.4 Tools and equipment are cleaned, checked and returned to storage in accordance with workplace requirements
 - 3.5 Surplus materials are returned to storage or disposed of in accordance with workplace requirements
 - 3.6 Work permits are signed off in accordance with workplace requirements
 - 3.7 Works records, reports and documentation are completed in accordance with workplace requirements

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the UET Transmission, Distribution and Rail Sector

Training Package Companion Volume Implementation Guide.

Unit Mapping Information

This unit replaces and is equivalent to UETTD RTP33 Maintain energised transmission lines using Barehand technique on a helicopter platform.

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=229bace1-b7bc-4653-9300-dffb13ecfad7>