



Australian Government

CPCPFS3032A Install distribution and range pipes

Release 1

CPCPFS3032A Install distribution and range pipes

Modification History

Prerequisite unit updated

Changes to performance criteria, required skills and knowledge, range statement and critical aspects

Not equivalent to CPCPFS3012A

Unit Descriptor

This unit of competency specifies the outcomes required to install distribution and range pipes to carry all commonly used fire extinguishing agents, above and below ground.

Application of the Unit

Site location for work application may be either domestic or commercial, and may be a new work site or an existing structure being renovated, extended, restored or maintained.

Licensing/Regulatory Information

In some jurisdictions, this unit of competency may form part of accreditation, licensing, legislative, regulatory or certification requirements.

Pre-Requisites

CPCPCM2043A Carry out WHS requirements

Employability Skills Information

This unit contains employability skills.

Elements and Performance Criteria Pre-Content

Elements describe the essential outcomes of a unit of competency.

Performance criteria describe the performance needed to demonstrate achievement of the element. Where bold italicised text is used, further information is detailed in the required skills and knowledge section and the range statement. Assessment of performance is to be consistent with the evidence guide.

Elements and Performance Criteria

- | | | | |
|---|-------------------------------------|-----|--|
| 1 | Prepare for work. | 1.1 | Approved plans and specifications are obtained from relevant authority. |
| | | 1.2 | Work health and safety (WHS) and environmental requirements associated with installing distribution and range pipes are adhered to throughout the work. |
| | | 1.3 | Quality assurance requirements are identified and adhered to according to workplace requirements. |
| | | 1.4 | Tasks are planned and sequenced in conjunction with others involved in or affected by the work. |
| | | 1.5 | Tools and equipment for installing distribution and range pipes, including personal protective equipment, are selected and checked for serviceability. |
| | | 1.6 | Work area is prepared to support efficient installation of distribution and range pipes. |
| 2 | Identify installation requirements. | 2.1 | System requirements are identified from job design criteria, specifications and standards. |
| | | 2.2 | Quantities of materials required are calculated from plans and specifications. |
| | | 2.3 | Allowances for fabrication and assembly are correctly determined and transferred. |
| | | 2.4 | Materials and equipment are identified, ordered and collected according to workplace procedures. |
| | | 2.5 | Materials and equipment are checked for compliance with standards, docket and order form, and for acceptable condition. |
| 3 | Install and test piping system. | 3.1 | Pipework is set out according to drawings, specifications and job instructions. |
| | | 3.2 | Pipe supports and fixings are installed to plans, manufacturer specifications and extinguishing materials . |

- 3.3 Piping and materials are installed according to the design drawings, job specifications and standards.
 - 3.4 Mechanical jointing systems are compliant with standards.
 - 3.5 Pipes are subjected to pressure testing according to standards or job specification.
 - 3.6 Test data is recorded in format required by the job specifications and quality assurance procedures.
 - 3.7 Installation is backfilled according to specifications.
 - 3.8 ***Sustainability principles and concepts*** are applied to installation.
-
- 4 Clean up.
 - 4.1 Work area is cleared and materials disposed of, reused or recycled according to legislation, regulations, codes of practice and job specification.
 - 4.2 Tools and equipment are cleaned, checked, maintained and stored according to manufacturer recommendations and workplace procedures.
 - 4.3 ***Information*** is accessed and documentation completed according to regulatory authorities and workplace requirements.

Required Skills and Knowledge

This section describes the skills and knowledge required for this unit.

Required skills

- communication skills to:
 - access information
 - determine requirements
 - enable clear and direct communication, using questioning to identify and confirm requirements, share information, listen and understand
 - follow and give instructions
 - use language and concepts appropriate to cultural differences
 - use and interpret non-verbal communication, such as hand signals
- initiative and enterprise skills to identify and report to appropriate personnel any faults in tools, equipment or materials
- literacy skills to:
 - complete workplace documentation
 - read and interpret:
 - documentation from a variety of sources
 - plans and specifications
 - record test results in writing
- numeracy skills to apply measurements and calculations
- planning and organising skills to:
 - plan and sequence tasks with others
 - plan and set out work
- teamwork skills to work with others to action tasks and relate to people from a range of cultural and ethnic backgrounds and with varying physical and mental abilities
- technical skills to install and test above ground distribution and range pipe system, fitted with branches, to supply water to a sprinkler system
- technology skills to:
 - access and understand site-specific instructions in a variety of media
 - use mobile communication technology

Required knowledge

- characteristics and application of different pipe fittings and fixture supports, including fixing and joining techniques
- excavation processes and procedures
- job safety analysis (JSA) and safe work method statements (SWMS)

- levelling and alignment processes
- materials relevant to installation of distribution and range pipes
- pressure test systems and procedures
- process of installing and testing distribution and range pipes
- processes for accessing information and for calculating material requirements
- relevant statutory and authorities' requirements related to installing distribution and range pipes
- SI system of measurement
- structural systems, building materials and building services
- workplace and equipment safety requirements

Evidence Guide

The evidence guide provides advice on assessment and must be read in conjunction with the performance criteria, required skills and knowledge, range statement and the Assessment Guidelines for the Training Package.

Overview of assessment

This unit of competency could be assessed in the workplace or a close simulation of the workplace environment providing that simulated or project-based assessment techniques fully replicate plumbing and services workplace conditions, materials, activities, responsibilities and procedures.

Critical aspects for assessment and evidence required to demonstrate competency in this unit

A person who demonstrates competency in this unit must be able to provide evidence of:

- locating, interpreting and applying relevant information, standards and specifications to install and test distribution and range pipes
- applying safety requirements throughout the work sequence, including electrical safety requirements and the use of personal protective clothing and equipment
- given the plans and specifications of an automated fire sprinkler system, installing and testing distribution and range pipes to provide a free-flowing and leak-free water supply to at least three branches to design criteria and standards, ensuring:
 - application of sustainability principles and concepts
 - correct identification of location, design and details of proposed installation
 - correct selection and use of appropriate processes, tools and equipment
 - completing all work to specification
 - compliance with regulations, standards and organisational quality procedures and processes
 - communicating and working effectively and safely with others.

Context of and specific resources for assessment

This competency is to be assessed using standard and authorised work practices, safety requirements and environmental constraints.

Assessment of essential underpinning knowledge will usually be conducted in an off-site context.

Assessment is to comply with relevant regulatory or

Australian standards' requirements.

Resource implications for assessment include:

- an induction procedure and requirement
- realistic tasks or simulated tasks covering the minimum task requirements
- relevant specifications and work instructions
- tools and equipment appropriate to applying safe work practices
- support materials appropriate to activity
- workplace instructions relating to safe work practices and addressing hazards and emergencies
- material safety data sheets
- research resources, including industry-related systems information.

Reasonable adjustments for people with disabilities must be made to assessment processes where required. This could include access to modified equipment and other physical resources, and the provision of appropriate assessment support.

Method of assessment

Assessment methods must:

- satisfy the endorsed Assessment Guidelines of the Construction, Plumbing and Services Training Package
- include direct observation of tasks in real or simulated work conditions, with questioning to confirm the ability to consistently identify and correctly interpret the essential underpinning knowledge required for practical application
- reinforce the integration of employability skills with workplace tasks and job roles
- confirm that competency is verified and able to be transferred to other circumstances and environments.

Validity and sufficiency of evidence requires that:

- competency will need to be demonstrated over a period of time reflecting the scope of the role and the practical requirements of the workplace
- where the assessment is part of a structured learning experience the evidence collected must relate to a number of performances assessed at different points in time and separated by further learning and practice, with a decision on competency only taken at the point when the assessor has complete

confidence in the person's demonstrated ability and applied knowledge

- all assessment that is part of a structured learning experience must include a combination of direct, indirect and supplementary evidence.

Assessment processes and techniques should as far as is practical take into account the language, literacy and numeracy capacity of the candidate in relation to the competency being assessed.

Supplementary evidence of competency may be obtained from relevant authenticated documentation from third parties, such as existing supervisors, team leaders or specialist training staff.

Range Statement

The range statement relates to the unit of competency as a whole. It allows for different work environments and situations that may affect performance. Bold italicised wording, if used in the performance criteria, is detailed below. Essential operating conditions that may be present with training and assessment (depending on the work situation, needs of the candidate, accessibility of the item, and local industry and regional contexts) may also be included.

Work health and safety is to be according to commonwealth, state and territory legislation and regulations and may include:

- handling of materials
- hazard control
- personal protective clothing and equipment prescribed under legislation, regulations and workplace policies and practices
- safe operating procedures, including recognising and preventing hazards associated with:
 - electricity
 - hazardous materials and substances
 - service lines
 - surrounding structures and facilities
 - trip hazards
 - use of tools and equipment
 - work site visitors and the public
 - working at heights
 - working in proximity to others
- use of firefighting equipment
- use of first aid equipment
- workplace environment and safety.

Environmental requirements cover water quality management and may include:

- clean-up protection
- stormwater protection
- waste management.

Distribution and range pipes may be installed:

- above and below ground.

Quality assurance requirements may include:

- Australian standards
- Environment Protection Authority (EPA)
- internal company quality assurance policy and risk management strategy
- International Standards Organisation
- site safety plan
- workplace operations and procedures.

Tools and equipment may include:

- angle grinders
- bending equipment
- chain blocks
- cutting and threading equipment
- elevated work platforms
- forklifts
- hand and power tools
- hand excavation tools
- hand trolleys
- hoists and jacks
- ladders
- lifting and load shifting equipment
- measuring equipment
- mechanical excavation equipment
- rollers
- scaffolds
- testing equipment
- welding equipment.

Extinguishing materials may include:

- foam
- gases
- powder
- water.

Sustainability principles and concepts:

- cover the current and future social, economic and environmental use of resources
- may include:
 - efficient use of material
 - appropriate recycling of material
 - efficient energy usage
 - disposing of waste material to ensure minimal environmental impact
 - selecting appropriate components to ensure minimal environmental impact.

Information may include:

- charts and hand drawings
- instructions issued by authorised organisational or external personnel
- manufacturer specifications and instructions
- material safety data sheets (MSDS)
- memos
- organisation work specifications and requirements
- plans and sketches
- regulatory and legislative requirements, particularly those pertaining to:
 - building codes
 - WHS and environmental requirements
 - plumbing regulations
- relevant Australian standards
- safe work procedures relating to installing distribution and range pipes
- signage
- verbal, written and graphical instructions
- work bulletins
- work schedules, plans and specifications.

Unit Sector(s)**Functional area**

Unit sector Plumbing and services

Custom Content Section

Not applicable.