



Australian Government

UEERE0077 Install battery storage equipment power conversion equipment to grid

Release: 1

UEERE0077 Install battery storage equipment power conversion equipment to grid

Modification History

Release 1. This is the first release of this unit of competency in the UEE Electrotechnology Training Package.

This unit replaces and is not equivalent to UEERE4001 Install, maintain and fault find battery storage systems for grid-connected photovoltaic systems. Modifications include:

- Unit title changed
- Unit application updated
- Prerequisites changed
- Significant amendments made to Elements and Performance Criteria
- Range of conditions updated
- Significant amendments to performance and knowledge evidence requirements and CVIG content developed
- Assessment conditions updated.

Application

This unit involves the skills and knowledge required to install battery storage equipment power conversion equipment (PCE) to grid.

It includes working safely and to industry installation standards, placing and securing system components accurately, making required circuit connections and completing the necessary installation documentation.

The skills and knowledge described in this unit require a licence or permit to practice in the workplace where work is carried out on electrical installations, which are designed to operate at voltages greater than 50 volt (V) alternating current (a.c.) or 120 V direct current (d.c.).

Competency development activities in this unit are subject to regulations directly related to licensing. Where a licence or permit to practice is not held, a relevant contract of training, such as an Australian Apprenticeship, is required.

Additional and/or other conditions may apply in some jurisdictions subject to regulations related to electrical work. Practice in the workplace and during training is also subject to work health and safety (WHS)/occupational health and safety (OHS) regulations.

Note: Those holding an Unrestricted Electrician's Licence or equivalent issued in an Australian state or territory meet the prerequisite requirements of UEEEL0012 Install low voltage wiring, appliances, switchgear and associated accessories. All other prerequisite requirements must be met.

Pre-requisite Unit

UEEEL0012 Install low voltage wiring, appliances, switchgear and associated accessories

UEERE0054 Conduct site survey for grid-connected photovoltaic and battery storage systems

Competency Field

Renewable and Sustainable Energy

Unit Sector

Electrotechnology

Elements and Performance Criteria

Elements describe the essential outcomes.

Performance criteria describe the performance needed to demonstrate achievement of the element.

1 Plan for the installation of battery storage equipment PCE to grid

- | | |
|------------|---|
| 1.1 | Nature of the installation is verified from design documentation and any design concerns identified are referred to designer |
| 1.2 | WHS/OHS processes and procedures for work are identified and applied in accordance with workplace procedures |
| 1.3 | Hazards associated with battery storage systems are identified and the risk control measures are listed in safe work method statements/job safety analysis |
| 1.4 | Work is planned in consultation with the customer and others impacted by the work and sequenced appropriately |
| 1.5 | Designer recommendations, relevant industry standards, regulations and manufacturer specifications are identified and applied to planning the system installation |
| 1.6 | Materials, tools, equipment and measuring devices required for installation are obtained in accordance with workplace procedures and checked for correct |

		operation and safety
	1.7	Live testing, measurement and isolation requirements determined and applied in accordance with WHS/OHS requirements and workplace procedures
2	Install battery storage equipment PCE to grid	
	2.1	Job safety analysis is undertaken or safe work method statement is prepared and used to inform work processes in accordance with regulations and workplace procedures
	2.2	Energy storage system components are installed in compliance with industry standards, regulations and job/manufacture specifications, and with sufficient access to enable terminations, adjustment and maintenance
	2.3	Wiring is terminated at components and associated equipment in accordance with manufacturer specifications and functional and regulatory requirements
	2.4	System components are programmed in accordance with design, relevant industry standards, regulations and manufacturer specifications
	2.5	Quality checks of installed apparatus are conducted in accordance with workplace procedures
	2.6	Testing and commissioning of the system is conducted in accordance with design documentation, regulations, relevant industry standards and manufacturer specifications
	2.7	Worksite is cleaned and made safe in accordance with workplace procedures
	2.8	‘As-installed’ system and associated equipment are documented, manuals produced, and system is handed over to required person/s as per legislation, regulations, industry standards and job requirements

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions can be found in the Companion Volume Implementation Guide.

Installation of battery storage equipment PCE to grid must include:

- installation of a section 5 or 6 system.

Unit Mapping Information

This unit replaces and is not equivalent to UEERE4001 Install, maintain and fault find battery storage systems for grid-connected photovoltaic systems.

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=b8a8f136-5421-4ce1-92e0-2b50341431b6>

Assessment Requirements for UEERE0077 Install battery storage equipment power conversion equipment to grid

Modification History

Release 1. This is the first release of this unit of competency in the UEE Electrotechnology Training Package.

This unit replaces and is not equivalent to UEERE4001 Install, maintain and fault find battery storage systems for grid-connected photovoltaic systems. Modifications include:

- Unit title changed
- Unit application updated
- Prerequisites changed
- Significant amendments made to Elements and Performance Criteria
- Range of conditions updated
- Significant amendments to performance and knowledge evidence requirements and CVIG content developed
- Assessment conditions updated.

Performance Evidence

Evidence required to demonstrate competence in this unit must be relevant to and satisfy all of the requirements of the elements and performance criteria on at least two occasions and include:

- interpreting system design and verifying installation compliance with relevant industry standards, manufacturer specifications, building codes and regulations and any noncompliance referred to designer
- applying relevant work health and safety (WHS)/occupational health and safety (OHS) requirements, including using risk control measures
- determining and applying live testing, measurement and isolation requirements
- installing battery storage systems including:
 - power conversion equipment (PCE) to grid and essential loads
 - balance of system to grid
 - programming components
- testing and commissioning the system
- completing required documentation
- instruct client on safe and correct system operation, recommended maintenance and system documentation.

Knowledge Evidence

Evidence required to demonstrate competence in this unit must be relevant to and satisfy all of the requirements of the elements, performance criteria and range of conditions and include knowledge of the following. Additional advice and definitions for some items is provided in the

UEE Training Package Companion Volume Implementation Guide (CVIG).

- grid-connected storage systems installations:
 - installation requirements including:
 - installing power conversion equipment (PCE) suitable for connecting to battery storage in accordance with system design documentation, relevant industry standards, regulations and manufacturer requirements
 - installing all balance of system equipment in accordance with system design documentation, relevant industry standards, regulations and manufacturer requirements
- types and applications of PCEs
- diagrams and drawings including:
 - electrical systems circuit diagrams of typical grid-connected energy storage systems including:
 - AC loads being supplied during periods when grid is unavailable
 - all major components
 - protection devices
 - earthing
 - isolation
 - switching
 - metering
 - equipment location plan/s to show the locations of equipment, fittings and cabling
 - single line diagrams of energy storage systems for grid-connected PV systems including modifications to switchboard to cater for specified loads
 - site diagrams to show the locations of equipment, fittings and cabling
- energy management strategies
- PCEs including:
 - differences between multimode and grid connect
 - output rating of a multimode PCE in relation to:
 - required maximum demand
 - capacity for battery charging
 - program parameters for a multimode inverter, for the correct operation of the system
 - blackout protection
- grid-connected storage systems fault finding:
 - fault finding procedures for individual equipment
 - fault finding procedures for interconnected systems
- maintenance requirements including relevant industry standards, regulations and manufacturer requirements
- grid-connected energy storage systems maintenance procedures including:
 - maintenance requirements for individual equipment
 - maintenance requirements for interconnected systems.
- grid-connected storage systems testing and commissioning procedures including:

- safe testing of equipment
- safe testing of system operation
- commissioning of energy storage system.

Assessment Conditions

As a minimum, assessors must satisfy applicable regulatory requirements, which include requirements in the Standards for Registered Training Organisations, current at the time of assessment.

As a minimum, assessment must satisfy applicable regulatory requirements, which include requirements in the Standards for Registered Training Organisations, current at the time of assessment.

Assessment must occur in workplace operational situations where it is appropriate to do so; where this is not appropriate, assessment must occur in simulated workplace operational situations that replicate workplace conditions.

Assessment processes and techniques must be appropriate to the language, literacy and numeracy requirements of the work being performed and the needs of the candidate.

Resources for assessment must include access to:

- Industry Standards
 - relevant industry standards
 - relevant industry product standards
- Documentation including reporting formats
 - manufacturer technical data site plans
 - system designer documentation relevant to installing the system
 - maintenance checklists and/or testing and commissioning sheet
- Measuring and testing equipment
 - multimeter insulation resistance tester clamp tester (DC and AC)
- Plant
 - an existing installed PV array along with the equipment to facilitate the installation of a battery storage system for grid-connected PV systems. This equipment shall comprise:
 - battery storage
 - multi-mode inverter/s
 - devices for interconnecting solar to system either including charge controller or an appropriate inverter and all required balance of system equipment including:
 - cables
 - protection and isolating devices
 - isolators and signage in accordance with relevant industry standards, regulations and industry guidelines
 - appropriate switchboard (or similar) to simulate interconnection of the system with an existing electrical installation
- Safety systems and personal protective equipment (PPE)

- example of a job safety analysis or safe work method statement form relevant for the practical installation; PPE related to the types of battery storage included in the system
- Software/Systems
 - programming software for the inverter/s and charge controller/s
- Specialist requirements
 - specific manufacturer specifications for the equipment included in the battery storage system for grid-connected PV systems including:
 - installation manuals and user guides for typical components and those provided for the practical installation
 - special tools as required for installing specific equipment
 - special testing tools or equipment required for testing and commissioning, maintenance and fault finding of specific equipment
- Tools and equipment
 - hand tools and power tools.

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=b8a8f136-5421-4ce1-92e0-2b50341431b6>