



Australian Government

UEPMNT448 Diagnose and repair faults in wind turbine generator control systems

Release: 1

UEPMNT448 Diagnose and repair faults in wind turbine generator control systems

Modification History

Release 1. This is the first release of this unit of competency in the UEP Generation Training Package.

Application

This unit involves the skills and knowledge required to diagnose and repair faults in large scale wind turbine generator control systems.

Diagnosing and repairing faults is the process of optimising the outcomes of large scale wind turbine generator control systems through regular inspections and verification of operational efficiency.

Competency in this unit requires the ability to gather data, interpret data to establish hypothesis about wind turbine generator electrical system fault, repair wind turbine generator electrical system fault and record wind turbine generator electrical system fault. Individuals will, in general, work under supervision in an electrical, electronic and/or mechanical equipment repair workshop or on site.

Power generation maintenance personnel are typically trained and authorised to receive permits to work.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

Note: Workplace practice

The application of the skills and knowledge described in this unit of competency may require a licence or training permit to practice in the workplace, where work is carried out on gas and electrical installations. Additional and/or other conditions may apply under state and territory legislative and regulatory licensing requirements.

Pre-requisite Unit

UEPMNT371 Maintain large scale wind turbine generators

UEPMNT443 Maintain wind turbine generator control systems

UEPMNT445 Diagnose and repair faults in large scale wind turbine generators

UEENEEG108A Troubleshoot and repair faults in low voltage electrical apparatus and circuits

UEENEEE102A Fabricate, assemble and dismantle utilities industry components

UEENEEE104A Solve problems in D.C. circuits

UEENEEE105A Fix and secure electrotechnology equipment

UEENEEE107A Use drawings, diagrams, schedules, standards, codes and specifications

UEENEEG006A Solve problems in single and three phase low voltage machines

UEENEEG033A Solve problems in single and three phase low voltage electrical apparatus and circuits

UEENEEG063A Arrange circuits, control and protection for general electrical installations

UEENEEG101A Solve problems in electromagnetic devices and related circuits

UEENEEG102A Solve problems in low voltage A.C. circuits

UEENEEG106A Terminate cables, cords and accessories for low voltage circuits

Competency Field

Maintenance

Unit Sector

Electricity generation

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Gather data

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

1.1 Data logging information and error codes are accessed, in accordance with workplace procedures

1.2 Sensory data on fault is gathered, in accordance with workplace procedures

1.3 Documentation is accessed, in accordance with workplace procedures, to support fault finding process

1.4 Built in fault indicators and error codes are, where appropriate, examined and interpreted

1.5 Reference to circuit diagrams, manufacturers' specifications, schematics or consultation with technical advisor is used to determine control system circuit function and characteristics

2 Interpret data to establish hypothesis about wind turbine generator control

2.1 Knowledge of wind turbine generator control systems and performance parameters is applied to interpretation

system fault		of fault data
	2.2	Wind turbine generator control systems faults are verified, or localised, using appropriate techniques, tools and test equipment, in accordance with workplace procedures
	2.3	Priorities are set for testing or replacement of specific components, wiring and connections in the wind turbine generator control system
3 Repair wind turbine generator control system fault	3.1	Risk analysis is undertaken and is communicated to work team and appropriate personnel, in accordance with workplace procedures
	3.2	Safety precautions including circuit isolations, physical barriers and other protective devices or systems are, where appropriate, used in accordance with workplace procedures
	3.3	Tests are conducted to ensure wind turbine generator control system fault has been isolated
	3.4	Faulty components are removed from service and are examined to identify cause of the problem
	3.5	Loose connections or wiring are repaired, in accordance with workplace procedures
	3.6	Faulty parts of wind turbine generator control system are removed and replaced with tested and operational parts
	3.7	Wind turbine generator control systems are tested, in accordance with workplace procedures, to ensure correct operation
	3.8	Repairs to complex faults are escalated, in accordance with workplace procedures to a technical adviser
4 Record wind turbine generator control system fault	4.1	Wind turbine generator control system's faulty components and parts are tagged, identified and stored, in accordance with workplace procedures
	4.2	Faults are recorded, in accordance with workplace procedures

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the Companion Volume Implementation Guide.

Unit Mapping Information

This unit replaces and is equivalent to UEPMNT448A Diagnose and repair faults in wind turbine generator control systems.

Links

Companion Volume implementation guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=1715b9fa-e7bd-441c-bb8d-cf22c9c825a8>