



Australian Government

UEPMNT449 Diagnose and repair mechanical systems faults in wind turbine generators

Release: 1

UEPMNT449 Diagnose and repair mechanical systems faults in wind turbine generators

Modification History

Release 1. This is the first release of this unit of competency in the UEP Generation Training Package.

Application

This unit involves the skills and knowledge required to diagnose and repair mechanical system faults in large scale wind turbine generators.

Diagnosing and repairing faults is the process of inspecting large scale wind turbine generators to identify problems and ensure repairs take place. The aim is to ensure that the overall delivery of the large scale wind turbine generators meets operational requirements.

Competency in this unit requires the ability gather data, interpret data to establish theory about wind turbine generator mechanical system faults, repair wind turbine generator mechanical system faults and record wind turbine generator mechanical system faults. Individuals will, in general, work under supervision in an electrical, electronic and/or mechanical equipment repair workshop or on site.

Power generation maintenance personnel are typically trained and authorised to receive permits to work.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

Note: Workplace practice

The application of the skills and knowledge described in this unit of competency may require a licence or training permit to practice in the workplace, where work is carried out on gas and electrical installations. Additional and/or other conditions may apply under state and territory legislative and regulatory licensing requirements.

Pre-requisite Unit

UEPMNT371 Maintain large scale wind turbines generators

UEPMNT444 Maintain wind turbine generator mechanical systems

UEPMNT445 Diagnose and repair faults in large scale wind turbine generators

UEENEEG108A Troubleshoot and repair faults in low voltage electrical apparatus and circuits

UEENEEE102A Fabricate, assemble and dismantle utilities industry components

UEENEEE104A Solve problems in D.C. circuits

UEENEEE105A Fix and secure electrotechnology equipment

UEENEEE107A Use drawings, diagrams, schedules, standards, codes and specifications

UEENEEG006A Solve problems in single and three phase low voltage machines

UEENEEG033A Solve problems in single and three phase low voltage electrical apparatus and circuits

UEENEEG063A Arrange circuits, control and protection for general electrical installations

UEENEEG101A Solve problems in electromagnetic devices and related circuits

UEENEEG102A Solve problems in low voltage A.C. circuits

UEENEEG106A Terminate cables, cords and accessories for low voltage circuits

Competency Field

Maintenance

Unit Sector

Electricity generation

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Gather data

2 Interpret data to establish hypothesis about wind turbine generator

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

- 1.1 Data logging information and error codes are accessed, in accordance with workplace procedures
- 1.2 Sensory data on fault is gathered, in accordance with workplace procedures
- 1.3 Documentation to support fault finding processes are accessed, in accordance with workplace procedures
- 1.4 Built in fault indicators and error codes, where appropriate, are examined and interpreted
- 1.5 Circuit or system function and characteristics are determined by reference to circuit diagrams, specifications, schematics or consultation with technical advisor

- 2.1 Wind turbine generator mechanical system and performance parameter knowledge is applied to

mechanical system fault	interpretation of fault data
	2.2 Wind turbine generator mechanical system faults are verified, or localised, using appropriate techniques, tools and test equipment, in accordance with workplace procedures
	2.3 Priorities are set for testing or replacement of specific components, wiring and connections in the wind turbine generator mechanical system
3 Repair wind turbine generator mechanical system fault	3.1 Risk analysis is undertaken and is communicated to work team and appropriate personnel, in accordance with workplace procedures
	3.2 Safety precautions including circuit isolations, physical barriers and other protective devices or systems are used, where appropriate, in accordance with workplace procedures
	3.3 Tests are conducted to ensure wind turbine generator mechanical system fault has been isolated
	3.4 Faulty components are removed from service and are examined to identify the cause of the problem
	3.5 Loose connections or wiring are repaired, in accordance with workplace procedures
	3.6 Wind turbine generator mechanical system parts likely to be cause of fault are removed and replaced with tested and operational parts
	3.7 Wind turbine generator mechanical systems are tested, in accordance with workplace procedures, to ensure correct operation
	3.8 Repairs to complex faults are escalated, in accordance with workplace procedures, if required, to a technical adviser
4 Record wind turbine generator mechanical system fault	4.1 Wind turbine generator mechanical system faulty components and parts are tagged, identified and stored, in accordance with workplace procedures
	4.2 Faults are recorded, in accordance with workplace procedures

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the Companion Volume Implementation Guide.

Unit Mapping Information

This unit replaces and is equivalent to UEPMNT449A Diagnose and repair mechanical systems faults in wind turbine generators.

Links

Companion Volume implementation guides are found in VETNet -
<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=1715b9fa-e7bd-441c-bb8d-cf22c9c825a8>