



Australian Government

UEPMNT450 Test and commission wind turbine generators

Release: 1

UEPMNT450 Test and commission wind turbine generators

Modification History

Release 1. This is the first release of this unit of competency in the UEP Generation Training Package.

Application

This unit involves the skills and knowledge required to conduct testing and commissioning of a wind turbine generator.

Testing and commissioning of wind turbine generators includes the assessment and verification that all equipment and components are operating efficiently and are meeting operational requirements.

Competency in this unit requires the ability to plan work, test systems equipment, test system and complete all work tasks. Individuals will, in general, work under supervision in an electrical, electronic and/or mechanical equipment repair workshop or on site.

Power generation maintenance personnel are typically trained and authorised to receive permits to work.

No licensing, legislative or certification requirements apply to this unit at the time of publication.

Note: Workplace practice

The application of the skills and knowledge described in this unit of competency may require a licence or training permit to practice in the workplace, where work is carried out on gas and electrical installations. Additional and/or other conditions may apply under state and territory legislative and regulatory licensing requirements.

Pre-requisite Unit

UEPMNT371 Maintain large scale wind turbine generators

UEPMNT444 Maintain wind turbine generator mechanical systems

UEPMNT443 Maintain wind turbine generator control systems

UEPMNT448 Diagnose and repair faults in wind turbine generator control systems

UEPMNT449 Diagnose and repair mechanical systems faults in wind turbine generators

UEPMNT445 Diagnose and repair faults in large scale wind turbine generators

UEENEEG108A Troubleshoot and repair faults in low voltage electrical apparatus and circuits

UEENEEE102A Fabricate, assemble and dismantle utilities industry components

UEENEEE104A Solve problems in D.C. circuits

UEENEEE105A Fix and secure electrotechnology equipment

UEENEEE107A Use drawings, diagrams, schedules, standards, codes and specifications

UEENEEG006A Solve problems in single and three phase low voltage machines

UEENEEG033A Solve problems in single and three phase low voltage electrical apparatus and circuits

UEENEEG063A Arrange circuits, control and protection for general electrical installations

UEENEEG101A Solve problems in electromagnetic devices and related circuits

UEENEEG102A Solve problems in low voltage A.C. circuits

UEENEEG106A Terminate cables, cords and accessories for

Competency Field

Maintenance

Unit Sector

Electricity generation

Elements and Performance Criteria

ELEMENTS

Elements describe the essential outcomes.

1 Plan and prepare for work

PERFORMANCE CRITERIA

Performance criteria describe the performance needed to demonstrate achievement of the element.

- 1.1** Requirements including scope of work and assigned roles are identified and confirmed with appropriate personnel or by site inspection, in accordance with workplace procedures
- 1.2** Work, Health and Safety (WHS)/Occupational Health and Safety (OHS) regulations, legislative requirements, industry standards, codes of practice, manufacturers' specifications, environmental obligations and workplace procedures are reviewed in preparation for work
- 1.3** Resources are obtained and inspected for compliance with job specification
- 1.4** Relevant plans, drawings and manuals are selected and used, in accordance with workplace procedures
- 1.5** Correct materials and components for work are obtained and inspected for compliance with job

specification

- 1.6** Commissioning is planned, sequenced and prioritised, in accordance with workplace procedures
 - 1.7** Potential hazards are identified and risk control measures are implemented, in accordance with workplace procedures
 - 1.8** Work area is accessed and prepared, in accordance with workplace procedures
- 2 Test systems equipment**
 - 2.1** Isolations are confirmed, where appropriate, in accordance with workplace procedures
 - 2.2** Wind turbine generator system equipment is visually inspected to ensure absence of any damage, defects and deterioration, in accordance with workplace procedures and commissioning plan
 - 2.3** Wind turbine generator system equipment is tested, in conjunction with other related systems and equipment, to ensure correct operation, in accordance with workplace procedures and commissioning plan
 - 2.4** Wind turbine generator wiring systems are checked and tested, in conjunction with other related systems and equipment, in accordance with workplace procedures and commissioning plan
- 3 Test system**
 - 3.1** Isolations are confirmed, where appropriate, in accordance with workplace procedures
 - 3.2** Wind turbine generator system, plant and equipment are set up and calibrated, in accordance with workplace procedures, operational requirements and manufacturers' specifications
 - 3.3** Wind turbine generator system is commissioned using appropriate plans, drawings and manuals, in accordance with workplace procedures and commissioning plan
 - 3.4** Wind turbine generator system is commissioned, in conjunction with other related systems and equipment, in accordance with workplace procedures and commissioning plan
 - 3.5** Wind turbine generator equipment is commissioned, in accordance with workplace procedures and

commissioning plan

3.6 Faulty wind turbine generator equipment is repaired or reported, in accordance with workplace procedures

3.7 Final inspection is carried out, in accordance with workplace procedures and commissioning plan

4 Complete work

4.1 Wind turbine generator commissioning is completed and appropriate personnel are notified, in accordance with workplace procedures

4.2 Work area is cleared of waste, cleaned, restored and secured, in accordance with workplace procedures

4.3 Tools and equipment are maintained and stored, in accordance with workplace procedures

4.4 Work completion details are finalised, in accordance with workplace procedures

Foundation Skills

Foundation skills essential to performance are explicit in the performance criteria of this unit of competency.

Range of Conditions

Range is restricted to essential operating conditions and any other variables essential to the work environment.

Non-essential conditions may be found in the Companion Volume Implementation Guide.

Unit Mapping Information

This unit replaces and is equivalent to UEPMT450A Test and commission wind turbine generators.

Links

Companion Volume implementation guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=1715b9fa-e7bd-441c-bb8d-cf22c9c825a8>