



Australian Government

Assessment Requirements for UETDRTO005 Inspect transmission structures, conductors and hardware

Release: 1

Assessment Requirements for UETDRT0005 Inspect transmission structures, conductors and hardware

Modification History

Release 1. This is the first release of this unit of competency in the UET Transmission, Distribution and Rail Sector Training Package Release 2.0.

Performance Evidence

Evidence required to demonstrate competence in this unit must be relevant to and satisfy all of the requirements of the elements and performance criteria on at least two separate occasions and include:

- applying relevant legislation, regulations, standards, codes of practice and organisational workplace requirements, including:
 - work health and safety (WHS)/occupational health and safety (OHS)
 - safe approach distances
- identifying hazards, assessing risks, identifying, applying and monitoring control measures
- obtaining, inspecting and using relevant personal protective equipment (PPE)
- organising and completing relevant work permits in accordance with workplace requirements
- undertaking inspections of structures, conductors and hardware using at least two (2) of the following methods:
 - visual
 - infra-red camera
 - X-ray
 - camera
 - binoculars/telescope
 - remote piloted aircraft (RPA)
 - thermographic
- recording inspection results in accordance with workplace requirements
- dealing with an unplanned event on at least one (1) occasion
- completing relevant work records, reports and documentation.

Knowledge Evidence

Evidence required to demonstrate competence in this unit must be relevant to and satisfy all of the requirements of the elements and performance criteria and include knowledge of:

- relevant legislation, regulations, standards, codes of practice and organisational workplace requirements, including:
 - WHS/OHS

- safe approach distances
- construction design clearances
- hazard, risk assessment and risk control requirements, including potential hazards
- types and application of PPE
- safe use of plant, tools and equipment
- application, purpose and types of permits
- events constituting an unplanned event or incident
- procedures for responding to an unplanned event or incident
- deterioration of structures, conductors and hardware, including:
 - relationship between steel, concrete and other materials
 - deterioration in steel and concrete
 - inspection procedures for deterioration
- inspection methods and techniques for:
 - below ground
 - ground level
 - above ground
 - reporting.

Assessment Conditions

Assessors must hold credentials specified within the Standards for Registered Training Organisations current at the time of assessment.

Assessment must satisfy the Principles of Assessment and Rules of Evidence and all regulatory requirements included within the Standards for Registered Training Organisations current at the time of assessment.

Assessment must occur in workplace operational situations, where it is appropriate to do so.

Where this is not appropriate, assessment must occur in simulated conditions involving realistic and authentic activities that replicate operational workplace conditions.

Assessment processes and techniques must be appropriate to the language, literacy and numeracy requirements of the work being performed and the needs of the candidate.

Resources for assessment must include access to:

- relevant and appropriate materials, tools, equipment and PPE currently used for inspecting transmission structures, conductors and hardware
- applicable documentation, including workplace requirements, relevant industry standards, regulations, codes of practice and operation manuals.

Links

Companion Volume Implementation Guides are found in VETNet -

<https://vetnet.gov.au/Pages/TrainingDocs.aspx?q=229bace1-b7bc-4653-9300-dffb13ecfad7>